DRINKING WATER SURVEILLANCE PROGRAM

HALDIMAND/ NORFOLK WATER SUPPLY SYSTEM

ANNUAL REPORT 1990

Ontario
Environment
Environnement

ISSN 1180-2162

HALDIMAND/NORFOLK WATER SUPPLY SYSTEM

DRINKING WATER SURVEILLANCE PROGRAM

ANNUAL REPORT 1990

AUGUST 1992

Cette publication technique
n'est disponible qu'en anglais.

PIBS 2029
Log 92-2302-261

EXECUTIVE SUMMARY

DRINKING WATER SURVEILLANCE PROGRAM

HALDIMAND/NORFOLK WATER SUPPLY SYSTEM
1990 ANNUAL REPORT

The Drinking Water Surveillance Program (DWSP) for Ontario is a monitoring program providing immediate, reliable, current information on drinking water quality. The DWSP officially began in April 1986 and is designed to eventually include all municipal supplies in Ontario. In 1990, 76 systems were being monitored.

The Haldimand/Norfolk water supply system is a conventional treatment plant which treats water from Lake Erie. The process consists of coagulation, flocculation, clarification (upflow clarifier), filtration and disinfection. This plant has a design capacity of 13.6 x 1000 m^3/day. The Haldimand/Norfolk water supply system serves a population of approximately 5,200.

Water at the plant and at two locations in the distribution system was sampled for the presence of approximately 180 parameters. Parameters were divided into the following groups: bacteriological, inorganic and physical (laboratory chemistry, field chemistry and metals), and organic (chloroaromatics, chlorophenols, pesticides and PCB, phenolics, polyaromatic hydrocarbons, specific pesticides and volatiles). Samples were analyzed for specific pesticides and chlorophenols twice a year in the spring and fall.

Table A is a summary of all results by group.

No known health related guidelines were exceeded.

The Haldimand/Norfolk water treatment plant, for the sample year 1990, produced good quality water and this was maintained in the distribution system.

TABLE A

DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS

SUMMARY TABLE BY SCAN

A POSITIVE VALUE DENOTES THAT THE RESULT IS GREATER THAN THE STATISTICAL LIMIT OF DETECTION AND IS QUANTIFIABLE
A '.' INDICATES THAT NO SAMPLE WAS TAKEN

SCAN	SITE	RAW 1			RAW 2			TREATED			SITE 1			SITE 2		
	TESTS	POSITIVE	%POSITIVE	TESTS	POSITIVE	%POSITIVE	TESTS	POSITIVE	%POSITIVE	TESTS	POSITIVE	%POSITIVE	TESTS	POSITIVE	%POSITIVE
BACTERIOLOGICAL	18	11	61	21	18	85	11	0	0	11	9	81	1	0	0
CHEMISTRY (FLD)	18	18	100	24	24	100	76	76	100	106	102	96	12	11	91
CHEMISTRY (LAB)	132	111	84	176	138	78	286	205	71	399	341	85	38	31	81
METALS	143	52	36	192	68	35	312	100	32	483	200	41	46	17	36
CHLOROAROMATICS	70	0	0	98	0	0	182	0	0	154	0	0	14	0	0
CHLOROPHENOLS	6	0	0	6	0	0	12	0	0	.	.	.	.	.	.
PAH	102	1	0	119	0	0	204	0	0	0	0	0	.	.	.
PESTICIDES & PCB	171	0	0	251	0	0	431	0	0	232	0	0	22	0	0
PHENOLICS	6	1	16	8	0	0	13	0	0	.	.	.	.	.	.
SPECIFIC PESTICIDES	29	0	0	33	0	0	63	0	0	11	0	0	1	0	0
VOLATILES	174	0	0	203	0	0	377	52	13	290	39	13	29	4	13
TOTAL	869	194		1131	248			433	216		691	316		63	221

DRINKING WATER SURVEILLANCE PROGRAM

HALDIMAND/NORFOLK WATER SUPPLY SYSTEM
1990 ANNUAL REPORT

INTRODUCTION

The Drinking Water Surveillance Program (DWSP) for Ontario is a monitoring program providing immediate, reliable, current information on drinking water quality. The DWSP officially began in April 1986 and is designed to eventually include all municipal supplies in Ontario. In 1990, 76 systems were being monitored.

Appendix A has a full description of the DWSP.

The DWSP was initiated for the Haldimand/Norfolk water supply system in the summer of 1989. A previous report was published for 1989.

PLANT DESCRIPTION

The Haldimand/Norfolk water supply system is a conventional treatment plant which treats water from Lake Erie. The process consists of coagulation, flocculation, clarification (upflow clarifier), filtration and disinfection. This plant has a design capacity of 13.6 x 1000 m^3/day. The Haldimand/Norfolk water supply system serves a population of approximately 5,200.

The sample day flows ranged from 3.3 x 1000 m^3/day to 5.1 x 1000 m^3/day.

General plant information is presented in Table 1 and a schematic of plant processes, chemical addition points and sampling locations in Figure 1.

SAMPLING AND ANALYSES

Sample lines in the plant were flushed prior to sampling to ensure that the water obtained was indicative of its origin and not residual water standing in the sample line.

At all distribution system locations two types of samples were obtained, a standing and a free flow. The standing sample consisted of water that had been in the household plumbing and service connection for a minimum of six hours. These samples were used to make an assessment of the change in the levels of inorganic compounds and metals, due to leaching from, or deposition on, the plumbing system. The only analyses carried out on the standing samples therefore, were General Chemistry and Metals. The free flow

sample represented fresh water from the distribution main, since the sample tap was flushed for five minutes prior to sampling.

Attempts were made to capture the same block of water at each sampling point by taking the retention time into consideration. Retention time was calculated by dividing the volume of water between two sampling points by sample day flow. For example, if it was determined that retention time within the plant was five hours, then there would be a five hour interval between the raw and treated sampling. Similarly, if it was estimated that it took approximately one day for the water to travel from the plant to the distribution system site, this site would be sampled one day after the treated water from the plant.

Stringent DWSP sampling protocols were followed to ensure that all samples were taken in a uniform manner (see Appendix B).

Plant operating personnel routinely analyze parameters for process control (Table 2).

Water at the plant and at one location in the distribution system was sampled for the presence of approximately 180 parameters. Parameters were divided into the following groups: bacteriological, inorganic and physical (laboratory chemistry, field chemistry and metals), and organic (chloroaromatics, chlorophenols, pesticides and PCB, phenolics, polyaromatic hydrocarbons, specific pesticides and volatiles). Samples were analyzed for specific pesticides and chlorophenols twice a year in the spring and fall. Laboratory analyses were conducted at the Ministry of the Environment facilities in Rexdale, Ontario.

RESULTS

Field measurements were recorded on the day of sampling and were entered onto the DWSP database as submitted by plant personnel.

Table 3 contains information on delay time between raw and treated water sampling, flow rate, and treatment chemical dosages.

Table 4 is a summary break-down of the number of water samples analyzed by parameter and by water type. The number of times that a positive or trace result was detected is also reported.

Positive denotes that the result is greater than the statistical limit of detection established by the Ministry of the Environment laboratory staff and is quantifiable. Trace (<T) denotes that the level measured is greater than the lowest value detectable by the method but lies so close to the detection limit that it cannot be confidently quantified.

Table 5 presents the results for parameters detected on at least one occasion.

Table 6 lists all parameters analyzed in the DWSP.

Associated guidelines and detection limits are also supplied on Tables 5 and 6. Parameters are listed alphabetically within each scan.

DISCUSSION

GENERAL

Water quality was judged by comparison with the Ontario Drinking Water Objectives publication (ODWOs). When an Ontario Drinking Water Objective (ODWO) was not available, guidelines/limits from other agencies were used. These guidelines were obtained from the Parameter Listing System database.

IN THIS REPORT, DISCUSSION IS LIMITED TO:

- **THE TREATED AND DISTRIBUTED WATER;**
- **ONLY THOSE PARAMETERS WITH CONCENTRATIONS ABOVE GUIDELINE VALUES; AND**
- **POSITIVE ORGANIC PARAMETERS DETECTED.**

BACTERIOLOGICAL

Guidelines for bacteriological sampling and testing of a supply are developed to maintain a proper supervision of its bacteriological quality. Routine monitoring programs usually require that multiple samples be collected in a given system. Full interpretation of bacteriological quality cannot be made on the basis of single samples.

Standard plate count is a test used to supplement routine analysis for coliform bacteria. The limit for standard plate count (at 35°C after 48 hours) in the ODWOs is 500 counts/mL (based on a geometric mean of 5 or more samples). DWSP bacteriological analysis of treated and distributed water was limited to standard plate count, which may indicate some deterioration in water quality if the guideline of 500 counts/mL is exceeded.

Standard plate count (membrane filtration) exceeded the ODWO Maximum Desirable Concentration of 500 counts/mL in 1 of 12 distributed water samples with a maximum reported value of 740.0 counts/mL.

INORGANIC & PHYSICAL

CHEMISTRY (FIELD)

It is desirable that the temperature of drinking water be less than 15°C. The palatability of water is enhanced by its coolness. A temperature below 15°C will tend to reduce the growth of nuisance organisms and hence minimize associated taste, colour, odour and corrosion problems. The temperature of the delivered water may increase in the distribution system due to the warming effect of the soil in late summer and fall and/or as a result of higher temperatures in the source water.

Field temperature exceeded the ODWO Maximum Desirable Concentration of 15°C in 8 of 24 treated and distributed water samples with a maximum reported value of 22.0°C.

CHEMISTRY (LAB)

The ODWOs indicate that a hardness level of between 80 and 100 mg/L as calcium carbonate for domestic waters provides an acceptable balance between corrosion and encrustation. Water supplies with a hardness greater than 200 mg/L are considered poor and would possess a tendency to form scale deposits and result in excessive soap consumption.

Hardness exceeded the ODWO Aesthetic or Recommended Operational Guideline of 80-100 mg/L in 25 of 25 treated and distributed water samples with a maximum reported value of 145.0 mg/L.

METALS

At present, there is no evidence that aluminum is physiologically harmful and no health limit for drinking water has been specified. The measure of aluminum in treated water is important to indicate the efficiency of the treatment process. The ODWOs indicate that a useful guideline is to maintain a residual below 100 ug/L as aluminum in the water leaving the plant, to avoid problems in the distribution system.

Aluminum exceeded the ODWO Aesthetic or Recommended Operational Guideline of 100 ug/L in 7 of 25 treated and distributed water samples with a maximum reported value of 190.0 ug/L.

ORGANIC

CHLOROAROMATICS

The results of the chloroaromatic scan showed that none were detected.

CHLOROPHENOLS

The results of the chlorophenol scan showed that none were detected.

POLYAROMATIC HYDROCARBONS (PAH)

The results of the PAH scan showed that none were detected in the treated or distributed water samples.

PESTICIDES & PCB

The results of the PCB scan showed that none were detected.

The results of the regular pesticide scan showed that none were detected above trace levels.

PHENOLICS

Phenolic compounds are present in the aquatic environment as a result of natural and/or industrial processes. The ODWOs recommend, as an operational guideline, that phenolic substances in drinking water not exceed 2.0 ug/L. This limit has been set primarily to prevent undesirable taste and odours, particularly in chlorinated water. No results were reported above trace levels.

SPECIFIC PESTICIDES

The results of the specific pesticides scan showed that none were detected.

VOLATILES

The detection of benzene, ethylbenzene, toluene and xylenes at low, trace levels may be a laboratory artifact derived from the analytical methodology.

Trihalomethanes (THMs) are produced during the water treatment process and will always occur in chlorinated waters. THMs are comprised of chloroform, chlorodibromomethane and dichlorobromomethane; bromoform occurs occasionally. Results are reported for the individual compounds as well as for total THMs. Only total THMs results are discussed.

Total THMs were found at positive levels in 23 of the 24 treated and distributed water samples analyzed. The maximum observed level was 61.4 ug/L. This was below the ODWO Maximum Acceptable Concentration of 350 ug/L.

CONCLUSIONS

The Haldimand/Norfolk water treatment plant, for the sample year 1990, produced good quality water and this was maintained in the distribution system.

No known health related guidelines were exceeded.

FIGURE 1

HALDIMAND-NORFOLK WATER TREATMENT PLANT



TABLE 1

DRINKING WATER SURVEILLANCE PROGRAM

PLANT GENERAL REPORT

WORKS #: 210001558
PLANT NAME: HALDIMAND-NORFOLK WSS

DISTRICT: HALDIMAND-NORFOLK
REGION: WEST CENTRAL
DISTRICT OFFICER :J. VOGT

UTM #: 175734504737400

PLANT SUPERINTENDENT: GARY KEMPENAAR

ADDRESS: BOX 400
NANTICOKE
N0A 1L0
(519-587-4565)

MUNICIPALITY: NANTICOKE
AUTHORITY: PROVINCIAL

PLANT INFORMATION

PLANT VOLUME:	-	(X 1000 M3)
DESIGN CAPACITY:	13.630	(X 1000 M3/DAY)
RATED CAPACITY:	4.250	(X 1000 M3/DAY)

MUNICIPALITY	POPULATION
HAGERSVILLE	2,298
JARVIS	1,270
TOWNSEND	639

TABLE 2
DRINKING WATER SURVEILLANCE PROGRAM
IN-PLANT MONITORING

PARAMETER	LOCATION	FREQUENCY
ALUMINUM	AFTER DISINFECTION	DAILY
COMBINED CHLORINE RESIDUAL	HIGHLIFT DISCHARGE	VARIABLE
FREE CHLORINE RESIDUAL	HIGHLIFT DISCHARGE	CONTINUOUS
TOTAL CHLORINE RESIDUAL	HIGHLIFT DISCHARGE	VARIABLE
PH	AFTER DISINFECTION RAW WATER	DAILY DAILY
TEMPERATURE	RAW WATER	VARIABLE
TURBIDITY	AFTER DISINFECTION RAW WATER	CONTINUOUS CONTINUOUS

TABLE 3
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS SAMPLE DAY CONDITIONS FOR 1990

			TREATMENT CHEMICAL DOSAGES (MG/L)		
			PRE CHLORINATION	COAGULATION	POST CHLORINATION
			CHLORINE	ALUM LIQUID	CHLORINE
DATE	DELAY * TIME(HRS)	FLOW (1000M3)			
JAN 10	.00	4.500	.89	14.70	.71
FEB 07	.00	3.870	.94	21.20	1.07
FEB 16	.00	.000		15.50	.94
FEB 27	1.57	4.800	.80	19.20	.65
MAR 07	1.50	5.100	.81	17.00	1.03
MAY 09	.00	3.800	.88	15.80	.82
JUN 05	48.00	3.300		12.30	.47
JUL 05	24.50	3.700	1.00	.07	1.10
AUG 08	8.00	4.500	3.01		1.29
SEP 05	.00	.000	2.13	12.60	1.47
NOV 08	.00	4.596	3.18	11.10	.32
DEC 03	24.00	3.500	3.30	15.20	.95

* THE DELAY TIME BETWEEN THE RAW AND TREATED WATER SAMPLING, SHOULD ESTIMATE THE RETENTION TIME.

TABLE 4
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS
SUMMARY TABLE OF RESULTS (1990)

SCAN	RAW 1			RAW 2			TREATED			SITE 1			SITE 2		
PARAMETER	TOTAL	POSITIVE	TRACE	TOTAL	POSITIVE	TRACE	TOTAL	POSITIVE	TRACE	TOTAL	POSITIVE	TRACE	TOTAL	POSITIVE	TRACE
BACTERIOLOGICAL															
FECAL COLIFORM MF	6	4	0	7	5	0	.	.	.	.	.	.	.	.	.
STANDRD PLATE CNT MF	.	.	.	.	.	.	11	0	0	11	9	0	1	0	0
TOTAL COLIFORM MF	6	1	0	7	6	0	.	.	.	.	.	.	.	.	.
T COLIFORM BCKGRD MF	6	6	0	7	7	0	.	.	.	.	.	.	.	.	.
*TOTAL GROUP BACTERIOLOGICAL	18	11	0	21	18	0	11	0	0	11	9	0	1	0	0
CHEMISTRY (FLD)															
FLD CHLORINE (COMB)	.	.	.	.	.	.	12	12	0	21	18	0	2	1	0
FLD CHLORINE FREE	.	.	.	.	.	.	13	13	0	21	20	0	2	2	0
FLD CHLORINE (TOTAL)	.	.	.	.	.	.	13	13	0	21	21	0	2	2	0
FLD PH	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
FLD TEMPERATURE	6	6	0	8	8	0	12	12	0	21	21	0	2	2	0
FLD TURBIDITY	6	6	0	8	8	0	13	13	0	1	1	0	2	2	0
*TOTAL SCAN CHEMISTRY (FLD)	18	18	0	24	24	0	76	76	0	106	102	0	12	11	0
CHEMISTRY (LAB)															
ALKALINITY	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
CALCIUM	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
CYANIDE	6	0	0	8	0	0	13	0	0	.	.	.	.	.	.
CHLORIDE	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
COLOUR	6	2	4	8	2	6	13	1	8	21	0	11	2	0	2
CONDUCTIVITY	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
DISS ORG CARBON	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
FLUORIDE	6	6	0	8	8	0	13	12	1	21	21	0	2	2	0
HARDNESS	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
IONCAL	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
LANGELIERS INDEX	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
MAGNESIUM	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
SODIUM	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
AMMONIUM TOTAL	6	4	1	8	0	2	13	0	0	21	1	5	2	1	1
NITRITE	6	4	2	8	1	7	13	1	4	21	8	9	2	0	2
TOTAL NITRATES	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
NITROGEN TOT KJELD	6	6	0	8	8	0	13	12	1	21	21	0	2	0	2
PH	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
PHOSPHORUS FIL REACT	6	0	4	8	2	4	13	0	3	.	.	.	.	.	.
PHOSPHORUS TOTAL	6	5	1	8	5	3	13	0	9	.	.	.	.	.	.
SULPHATE	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
TURBIDITY	6	6	0	8	8	0	13	10	3	21	17	4	2	2	0
*TOTAL SCAN CHEMISTRY (LAB)	132	111	12	176	138	22	286	205	29	399	341	29	38	31	7

TABLE 4
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS
SUMMARY TABLE OF RESULTS (1990)

SITE	RAW 1			RAW 2			TREATED			SITE 1			SITE 2		
SCAN PARAMETER	TOTAL	POSITIVE	TRACE	TOTAL	POSITIVE	TRACE	TOTAL	POSITIVE	TRACE	TOTAL	POSITIVE	TRACE	TOTAL	POSITIVE	TRACE
METALS															
SILVER	6	0	0	8	0	0	13	0	0	21	0	0	2	0	0
ALUMINUM	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
ARSENIC	6	0	6	8	1	7	13	0	9	21	0	21	2	0	0
BARIUM	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
BORON	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
BERYLLIUM	6	0	0	8	0	3	13	0	1	21	0	2	2	0	0
CADMIUM	6	0	1	8	0	0	13	0	2	21	0	1	2	0	0
COBALT	6	0	6	8	0	7	13	0	12	21	0	18	2	0	2
CHROMIUM	6	0	4	8	0	4	13	0	10	21	0	19	2	0	2
COPPER	6	1	5	8	0	8	13	0	13	21	21	0	2	1	1
IRON	6	1	5	8	5	3	13	0	1	21	0	7	2	1	0
MERCURY	5	0	1	8	0	1	13	0	3	.	.	.	.	.	.
MANGANESE	6	6	0	8	8	0	13	11	2	21	11	10	2	1	1
MOLYBDENUM	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
NICKEL	6	1	4	8	0	3	13	1	8	21	2	12	2	0	2
LEAD	6	1	4	8	0	8	13	0	7	21	13	8	2	1	1
ANTIMONY	6	5	1	8	2	6	13	7	6	21	18	3	2	2	0
SELENIUM	6	0	2	8	0	2	13	0	7	21	0	14	2	0	2
STRONTIUM	6	6	0	8	8	0	13	13	0	21	21	0	2	2	0
TITANIUM	6	1	5	8	4	4	13	4	9	21	6	15	2	0	2
THALLIUM	6	0	0	8	0	2	13	0	1	21	0	1	2	0	0
URANIUM	6	0	6	8	0	8	13	0	13	21	0	21	2	0	2
VANADIUM	6	1	5	8	1	7	13	11	2	21	5	16	2	0	2
ZINC	6	5	1	8	7	1	13	1	12	21	19	2	2	1	1
*TOTAL SCAN METALS	143	52	56	192	68	74	312	100	118	483	200	170	46	17	18
*TOTAL GROUP INORGANIC & PHYSICAL	293	181	68	392	230	96	674	381	147	988	643	199	96	59	25
CHLOROAROMATICS															
HEXACHLOROBUTADIENE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
123 TRICHLOROBENZENE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
1234 T-CHLOROBENZENE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
1235 T-CHLOROBENZENE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
124 TRICHLOROBENZENE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
1245 T-CHLOROBENZENE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
135 TRICHLOROBENZENE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
HCB	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
HEXACHLOROETHANE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
OCTACHLOROSTYRENE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
PENTACHLOROBENZENE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
236 TRICHLOROTOLUENE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
245 TRICHLOROTOLUENE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
26A TRICHLOROTOLUENE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
*TOTAL SCAN CHLOROAROMATICS	70	0	0	98	0	0	182	0	0	154	0	0	14	0	0

TABLE 4
ORINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS
SUMMARY TABLE OF RESULTS (1990)

SCAN PARAMETER	SITE RAW 1 TOTAL	RAW 1 POSITIVE	RAW 1 TRACE	RAW 2 TOTAL	RAW 2 POSITIVE	RAW 2 TRACE	TREATED TOTAL	TREATED POSITIVE	TREATED TRACE	SITE 1 TOTAL	SITE 1 POSITIVE	SITE 1 TRACE	SITE 2 TOTAL	SITE 2 POSITIVE	SITE 2 TRACE
CHLOROPHENOLS															
234 TRICHLOROPHENOL	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
2345 T-CHLOROPHENOL	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
2356 T-CHLOROPHENOL	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
245-TRICHLOROPHENOL	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
246-TRICHLOROPHENOL	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
PENTACHLOROPHENOL	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
*TOTAL SCAN CHLOROPHENOLS	6	0	0	6	0	0	12	0	0	0	0	0	0	0	0
PAH															
PHENANTHRENE	6	1	0	7	0	0	12	0	0	0	0	0	.	.	.
ANTHRACENE	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
FLUORANTHENE	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
PYRENE	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
BENZO(A)ANTHRACENE	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
CHRYSENE	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
DIMETH. BENZ(A)ANTHR	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
BENZO(E) PYRENE	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
BENZO(B) FLUORANTHEN	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
PERYLENE	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
BENZO(K) FLUORANTHEN	6	0	1	7	0	0	12	0	0	0	0	0	.	.	.
BENZO(A) PYRENE	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
BENZO(G,H,I) PERYLEN	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
DIBENZO(A,H) ANTHRAC	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
INDENO(1,2,3-C,D) PY	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
BENZO(B) CHRYSENE	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
CORONENE	6	0	0	7	0	0	12	0	0	0	0	0	.	.	.
*TOTAL SCAN PAH	102	1	1	119	0	0	204	0	0	0	0	0	0	0	0
PESTICIDES & PCB															
ALDRIN	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
ALPHA BHC	5	0	3	7	0	2	13	0	8	11	0	7	1	0	0
BETA BHC	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
LINDANE	5	0	0	7	0	0	13	0	1	11	0	0	1	0	0
ALPHA CHLORDANE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
GAMMA CHLORDANE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
DIELDRIN	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
METHOXYCHLOR	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
ENDOSULFAN 1	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
ENDOSULFAN II	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
ENDRIN	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
ENDOSULFAN SULPHATE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
HEPTACHLOR EPOXIDE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
HEPTACHLOR	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
MIREX	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
OXYCHLORDANE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
OPDDT	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
PCB	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
DDD	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
PPDDE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0

TABLE 4
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS
SUMMARY TABLE OF RESULTS (1990)

SCAN PARAMETER	SITE RAW 1 TOTAL	RAW 1 POSITIVE	RAW 1 TRACE	RAW 2 TOTAL	RAW 2 POSITIVE	RAW 2 TRACE	TREATED TOTAL	TREATED POSITIVE	TREATED TRACE	SITE 1 TOTAL	SITE 1 POSITIVE	SITE 1 TRACE	SITE 2 TOTAL	SITE 2 POSITIVE	SITE 2 TRACE
PPDDT	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
AMETRINE	5	0	0	8	0	0	12	0	0	.	.	.	.	.	.
ATRAZINE	5	0	2	8	0	1	12	0	3	.	.	.	.	.	.
ATRATONE	5	0	0	8	0	0	12	0	0	.	.	.	.	.	.
CYANAZINE (BLADEX)	5	0	0	8	0	0	12	0	0	.	.	.	.	.	.
DESETHYLATRAZINE	5	0	0	8	0	0	12	0	0	.	.	.	.	.	.
D-ETHYL SIMAZINE	5	0	0	8	0	0	12	0	0	.	.	.	.	.	.
PROMETONE	5	0	0	8	0	0	12	0	0	.	.	.	.	.	.
PROPAZINE	5	0	0	8	0	0	12	0	0	.	.	.	.	.	.
PROMETRYNE	5	0	0	8	0	0	12	0	0	.	.	.	.	.	.
METRIBUZIN (SENCOR)	5	0	0	8	0	0	12	0	0	.	.	.	.	.	.
SIMAZINE	5	0	0	8	0	0	12	0	0	.	.	.	.	.	.
ALACHLOR (LASSO)	5	0	0	8	0	0	12	0	0	.	.	.	.	.	.
METOLACHLOR	5	0	0	8	0	0	12	0	0	.	.	.	.	.	.
HEXACLCYCLOPENTADIEN	1	0	0	.	.	.	2	0	0	1	0	0	1	0	0
*TOTAL SCAN PESTICIDES & PCB	171	0	5	251	0	3	431	0	12	232	0	7	22	0	0
PHENOLICS															
PHENOLICS	6	1	3	8	0	5	13	0	6	.	.	.	.	.	.
*TOTAL SCAN PHENOLICS	6	1	3	8	0	5	13	0	6	0	0	0	0	0	0
SPECIFIC PESTICIDES															
TOXAPHENE	5	0	0	7	0	0	13	0	0	11	0	0	1	0	0
2,4,5-T	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
2,4-D	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
2,4-DB	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
2,4 D PROPIONIC ACID	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
DICAMBA	0	0	0	1	0	0	1	0	0	.	.	.	.	.	.
PICHLORAM	0	0	0	0	0	0	0	0	0	.	.	.	.	.	.
SILVEX	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
DIAZINON	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
DICHLOROVOS	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
CHLORPYRIFOS	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
ETHION	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
AZINPHOS-METHYL	0	0	0	0	0	0	0	0	0	.	.	.	.	.	.
MALATHION	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
MEVINPHOS	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
METHYL PARATHION	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
METHYLTRITHION	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
PARATHION	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
PHORATE	0	0	0	1	0	0	1	0	0	.	.	.	.	.	.
RELDAN	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
RONNEL	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
AMINOCARB	0	0	0	0	0	0	0	0	0	.	.	.	.	.	.
BENONYL	0	0	0	0	0	0	0	0	0	.	.	.	.	.	.
BUX	0	0	0	0	0	0	0	0	0	.	.	.	.	.	.
CARBOFURAN	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
CICP	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
DIALLATE	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.

TABLE 4
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS
SUMMARY TABLE OF RESULTS (1990)

SITE	RAW 1			RAW 2			TREATED			SITE 1			SITE 2		
SCAN PARAMETER	TOTAL	POSITIVE	TRACE	TOTAL	POSITIVE	TRACE	TOTAL	POSITIVE	TRACE	TOTAL	POSITIVE	TRACE	TOTAL	POSITIVE	TRACE
EPTAM	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
IPC	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
PROPOXUR	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
CARBARYL	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
BUTYLATE	1	0	0	1	0	0	2	0	0	.	.	.	.	.	.
*TOTAL SCAN SPECIFIC PESTICIDES	29	0	0	33	0	0	63	0	0	11	0	0	1	0	0
VOLATILES															
BENZENE	6	0	0	7	0	1	13	0	5	10	0	2	1	0	0
TOLUENE	6	0	0	7	0	1	13	0	12	10	0	4	1	0	0
ETHYLBENZENE	6	0	2	7	0	1	13	0	9	10	0	7	1	0	1
P-XYLENE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
M-XYLENE	6	0	0	7	0	0	13	0	2	10	0	3	1	0	0
O-XYLENE	6	0	0	7	0	0	13	0	5	10	0	5	1	0	0
STYRENE	6	0	4	7	0	0	13	0	3	10	0	7	1	0	1
1,1 DICHLOROETHYLENE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
METHYLENE CHLORIDE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
T1,2DICHLOROETHYLENE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
1,1 DICHLOROETHANE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
CHLOROFORM	6	0	3	7	0	0	13	13	0	10	10	0	1	1	0
111, TRICHLOROETHANE	6	0	0	7	0	0	13	0	1	10	0	0	1	0	0
1,2 DICHLOROETHANE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
CARBON TETRACHLORIDE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
1,2 DICHLOROPROPANE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
TRICHLOROETHYLENE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
DICHLOROBROMOMETHANE	6	0	3	7	0	0	13	13	0	10	10	0	1	1	0
112 TRICHLOROETHANE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
CHLORODIBROMOMETHANE	6	0	1	7	0	0	13	13	0	10	9	0	1	1	0
T-CHLOROETHYLENE	6	0	0	7	0	0	13	0	1	10	0	0	1	0	0
BROMOFORM	6	0	0	7	0	0	13	0	13	10	0	10	1	0	1
1122 T-CHLOROETHANE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
CHLOROBENZENE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
1,4 DICHLOROBENZENE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
1,3 DICHLOROBENZENE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
1,2 DICHLOROBENZENE	6	0	0	7	0	0	13	0	0	10	0	0	1	0	0
ETHLYENE DIBROMIDE	6	0	0	7	0	0	13	0	0	10	0	1	1	0	0
TOTL TRIHALOMETHANES	6	0	1	7	0	0	13	13	0	10	10	0	1	1	0
*TOTAL SCAN VOLATILES	174	0	14	203	0	3	377	52	51	290	39	39	29	4	3
*TOTAL GROUP ORGANIC	558	2	23	718	0	11	1282	52	69	687	39	46	66	4	3

KEY TO TABLE 5 and 6

A ONTARIO DRINKING WATER OBJECTIVES (ODWO)
- 1. Maximum Acceptable Concentration (MAC)
- 1+. MAC for Total Trihalomethanes
- 2. Interim Maximum Acceptable Concentration (IMAC)
- 3. Aesthetic Objective (AO)
- 3*. AO for Total Xylenes
- 4. Recommended Operational Guideline

B HEALTH & WELFARE CANADA (H&W)
- 1. Maximum Acceptable Concentration (MAC)
- 2. Proposed MAC
- 3. Interim MAC
- 4. Aesthetic Objective (AO)

C WORLD HEALTH ORGANIZATION (WHO)
- 1. Guideline Value (GV)
- 2. Tentative GV
- 3. Aesthetic GV

D US ENVIRONMENTAL PROTECTION AGENCY (EPA)
- 1. Maximum Contaminant Level (MCL)
- 2. Suggested No-Adverse Effect Level (SNAEL)
- 3. Lifetime Health Advisory
- 4. EPA Ambient Water Quality Criteria
- 4T. EPA Ambient Water Quality Criteria for Total PAH

F EUROPEAN ECONOMIC COMMUNITY (EEC)
- 1. Health Related Guideline Level
- 2. Aesthetic Guideline Level
- 3. Maximum Admissable Concentration (MADC)

G CALIFORNIA STATE DEPARTMENT OF HEALTH-GUIDELINE VALUE

I NEW YORK STATE AMBIENT WATER GUIDELINE

N/A NONE AVAILABLE

LABORATORY RESULTS, REMARK DESCRIPTIONS

.	No Sample Taken
BDL	Below Minimum Measurement Amount
<T	Greater Than Detection Limit But Not Confident (SEE INTERPRETATION OF RESULTS ABOVE)
>	Results Are Greater Than The Upper Limit
<=>	Approximate Result
!CS	No Data: Contamination Suspected
!IL	No Data: Sample Incorrectly Labelled
!IS	No Data: Insufficient Sample
!IV	No Data: Inverted Septum
!LA	No Data: Laboratory Accident
!LD	No Data: Test Queued After Sample Discarded
!NA	No Data: No Authorization To Perform Reanalysis
!NP	No Data: No Procedure
!NR	No Data: Sample Not Received
!OP	No Data: Obscured Plate
!QU	No Data: Quality Control Unacceptable
!PE	No Data: Procedural Error - Sample Discarded
!PH	No Data: Sample pH Outside Valid Range
!RE	No Data: Received Empty
!RO	No Data: See Attached Report (no numeric results)
!SM	No Data: Sample Missing
!SS	No Data: Send Separate Sample Properly Preserved
!UI	No Data: Indeterminant Interference
!TX	No Data: Time Expired
A3C	Approximate, Total Count Exceeded 300 Colonies
APL	Additional Peak, Large, Not Priority Pollutant
APS	Additional Peak, Less Than, Not Priority Pollutant
CIC	Possible Contamination, Improper Cap
CRO	Calculated Result Only
PPS	Test Performed On Preserved Sample
RMP	P and M-Xylene Not Separated
RRV	Rerun Verification
RVU	Reported Value Unusual
SPS	Several Peaks, Small, Not Priority Pollutant

UCR		Unreliable: Could Not Confirm By Reanalysis
UCS		Unreliable: Contamination Suspected
UIN		Unreliable: Indeterminate Interference
XP		Positive After X Number Of Hours
T#	(T06)	Result Taken After # Hours

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
BACTERIOLOGICAL							
FECAL COLIFORM MF (CT/100ML)			DET'N LIMIT = 0	GUIDELINE = 0 (A1)			
JAN	.	2	.	.	.	.	.
FEB	.	1	.	.	.	.	.
MAR	.	1	.	.	.	.	.
APR	.	2	.	.	.	.	.
MAY	.	0	.	.	.	.	.
JUN	.	2	.	.	.	.	.
JUL	180	.	.	.	.	.	.
AUG	2	.	.	.	.	.	.
SEP	BDL	.	.	.	.	.	.
OCT	2	.	.	.	.	.	.
NOV	BDL	.	.	.	.	.	.
DEC	4	.	.	.	.	.	.
STANDRD PLATE CNT MF (COUNTS/ML)			DET'N LIMIT = 0	GUIDELINE = 500/ML (A3)			
JAN	.	.	1 <=>	.	51	.	.
FEB	.	.	1 <=>	.	10	.	.
MAR	.	.	0 <=>	.	37	.	.
APR	.	.	4 <=>	.	18	.	.
MAY	.	.	1 <=>	.	2 <=>	.	.
JUN	.	.	.	.	2 <=>	.	.
JUL	.	.	0 <=>	.	45	.	.
AUG	.	.	1 <=>	.	11	.	.
SEP	.	.	5 <=>	.	120	.	.
OCT	.	.	1 <=>	.	59	.	.
NOV	.	.	0 <=>	.	740	.	.
DEC	.	.	0 <=>	.	.	.	0 <=>
TOTAL COLIFORM MF (CT/100ML)			DET'N LIMIT = 0	GUIDELINE = 5/100ML(A1)			
JAN	.	2300	.	.	.	.	.
FEB	.	112	.	.	.	.	.
MAR	.	36	.	.	.	.	.
APR	.	10	.	.	.	.	.
MAY	.	28	.	.	.	.	.
JUN	.	80 <=>	.	.	.	.	.
JUL	4000 <=>	.	.	.	.	.	.
AUG	3000 <=>	.	.	.	.	.	.
SEP	400 <=>	.	.	.	.	.	.
OCT	100 <=>	.	.	.	.	.	.
NOV	20 <=>	.	.	.	.	.	.
DEC	130	.	.	.	.	.	.

TABLE 5
ORINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANOING	FREE FLOW
T COLIFORM BCKGRD MF (CT/100ML)		DET'N LIMIT = 0		GUIDELINE = N/A			
JAN	.	75000	.	.	.	.	.
FEB	.	2600	.	.	.	.	.
MAR	.	168	.	.	.	.	.
APR	.	230	.	.	.	.	.
MAY	.	1360	.	.	.	.	.
JUN	.	48000 >	.	.	.	.	.
JUL	00000	.	.	.	.	.	.
AUG	00000 >	.	.	.	.	.	.
SEP	6900	.	.	.	.	.	.
OCT	2040	.	.	.	.	.	.
NOV	660	.	.	.	.	.	.
DEC	2200	.	.	.	.	.	.

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
CHEMISTRY (FLD)							
FLD CHLORINE (COMB) (MG/L)			DET'N LIMIT = 0	GUIDELINE = N/A			
JAN	.	.	.150	.100	.100	.	.
FEB	.	.	.100	.000	.100	.	.
MAR	.	.	.170	.200	.100	.	.
APR	.	.	.	.100	.200	.	.
MAY	.	.	.080	.100	.100	.	.
JUN	.	.	.050	.100	.100	.	.
JUL	.	.	.050	.050	.100	.	.
AUG	.	.	.300	.200	.100	.	.
SEP	.	.	.200	.100	.000	.	.
OCT	.	.	.050	.100	.000	.	.
NOV	.	.	.160	.	.100	.	.
DEC	.	.	.050	.	.	.000	.050
FLD CHLORINE FREE (MG/L)			DET'N LIMIT = 0	GUIDELINE = N/A			
JAN	.	.	.750	.000	.300	.	.
FEB	.	.	.900	.100	.200	.	.
MAR	.	.	.750	.100	.300	.	.
APR	.	.	.620	.100	.300	.	.
MAY	.	.	.600	.100	.200	.	.
JUN	.	.	.250	.100	.200	.	.
JUL	.	.	.450	.050	.100	.	.
AUG	.	.	.400	.100	.300	.	.
SEP	.	.	1.000	.200	.300	.	.
OCT	.	.	1.100	.050	.100	.	.
NOV	.	.	.940	.	.100	.	.
DEC	.	.	.950	.	.	.400	.350
FLD CHLORINE (TOTAL) (MG/L)			DET'N LIMIT = 0	GUIDELINE = N/A			
JAN	.	.	.900	.100	.400	.	.
FEB	.	.	1.000	.100	.300	.	.
MAR	.	.	.920	.300	.400	.	.
APR	.	.	.620	.200	.500	.	.
MAY	.	.	.680	.200	.300	.	.
JUN	.	.	.300	.200	.300	.	.
JUL	.	.	.500	.100	.200	.	.
AUG	.	.	.700	.300	.400	.	.
SEP	.	.	1.200	.300	.300	.	.
OCT	.	.	1.150	.150	.100	.	.
NOV	.	.	1.100	.	.200	.	.
DEC	.	.	1.000	.	.	.400	.400

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
FLD PH (OMNSLESS)		**DET'N LIMIT = N/A**		**GUIDELINE = 6.5-8.5(A4)**			
JAN	.	7.700	7.300	7.600	7.400	.	.
FEB	.	7.900	7.700	7.600	7.600	.	.
MAR	.	7.600	7.100	7.600	7.600	.	.
APR	.	7.400	7.100	7.800	7.600	.	.
MAY	.	7.500	7.100	7.400	7.400	.	.
JUN	.	7.100	6.900	7.600	7.800	.	.
JUL	7.400	.	7.200	7.600	7.600	.	.
AUG	7.500	.	7.000	7.600	7.600	.	.
SEP	7.000	.	6.800	7.600	7.600	.	.
OCT	7.000	.	6.700	7.600	7.600	.	.
NOV	7.300	.	7.000	.	7.700	.	.
DEC	7.300	.	6.900	.	.	6.900	6.900
FLD TEMPERATURE (DEG.C)		**DET'N LIMIT = N/A**		**GUIDELINE = 15 (A3)**			
JAN	.	2.500	5.000	19.000	9.000	.	.
FEB	.	4.000	7.000	19.000	9.000	.	.
MAR	.	5.000	10.000	14.000	8.500	.	.
APR	.	6.500	6.500	19.000	9.500	.	.
MAY	.	9.500	11.000	21.000	11.000	.	.
JUN	.	16.000	10.000	18.000	13.500	.	.
JUL	19.500	.	19.500	22.000	16.500	.	.
AUG	22.000	.	22.000	22.000	18.500	.	.
SEP	23.000	.	21.000	23.000	19.000	.	.
OCT	17.000	.	16.000	20.000	18.000	.	.
NOV	11.000	.	13.000	.	15.000	.	.
DEC	7.000	.	8.000	.	.	8.000	9.000
FLD TURBIDITY (FTU)		**DET'N LIMIT = N/A**		**GUIDELINE = 1 (A1)**			
JAN	.	3.000	.100	.	.	.	.
FEB	.	5.900	.200	.	.	.	.
MAR	.	1.400	.100	.	.	.	.
APR	.	5.600	.090	.	.	.	.
MAY	.	8.000	.080	.	.	.	.
JUN	.	4.600	.080	.	.	.	.
JUL	3.300	.	.060	.	.	.	.
AUG	2.800	.	.070	.	.	.	.
SEP	3.200	.	.080	.	.	.	.
OCT	3.500	.	.080	.	.	.	.
NOV	2.000	.	.080	.	.080	.	.
DEC	4.200	.	.130	.	.	.080	.100

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
CHEMISTRY (LAB)							
ALKALINITY (MG/L)		DET'N LIMIT = 0.2		GUIDELINE = 30-500 (A4)			
JAN	.	105.900	99.400	103.600	102.700	.	.
FEB	.	101.900	97.500	102.700	100.800	.	.
MAR	.	104.000	95.900	98.500	99.100	.	.
APR	.	101.100	96.100	99.400	98.700	.	.
MAY	.	98.500	92.300	98.400	97.800	.	.
JUN	.	98.100	91.300	96.600	96.500	.	.
JUL	99.100	.	91.300	96.900	95.800	.	.
AUG	97.600	.	92.700	97.400	96.600	.	.
SEP	94.800	.	90.100	96.600	96.000	.	.
OCT	97.900	.	96.200	103.200	102.500	.	.
NOV	101.100	.	97.400	.	100.400	.	.
DEC	101.300	.	95.900	.	.	100.900	99.700
CALCIUM (MG/L)		DET'N LIMIT = 0.2		GUIDELINE = 100 (F2)			
JAN	.	40.200	41.000	42.400	42.200	.	.
FEB	.	38.200	38.600	43.000	41.800	.	.
MAR	.	40.900	39.800	40.160	40.810	.	.
APR	.	38.000	38.800	40.800	40.400	.	.
MAY	.	36.700	36.200	38.800	39.200	.	.
JUN	.	35.500	36.800	39.200	39.200	.	.
JUL	37.000	.	37.600	39.400	39.000	.	.
AUG	37.300	.	35.400	39.000	38.800	.	.
SEP	36.200	.	36.600	38.400	39.600	.	.
OCT	36.400	.	37.800	40.600	40.200	.	.
NOV	36.800	.	38.200	.	40.800	.	.
DEC	37.900	.	37.400	.	.	39.600	39.700
CHLORIDE (MG/L)		DET'N LIMIT = 0.2		GUIDELINE = 250 (A3)			
JAN	.	15.900	17.800	17.300	17.200	.	.
FEB	.	14.800	17.200	17.200	16.700	.	.
MAR	.	15.200	14.500	13.100	16.700	.	.
APR	.	14.900	16.000	16.400	16.100	.	.
MAY	.	14.600	16.100	16.600	16.400	.	.
JUN	.	14.700	16.400	16.800	16.700	.	.
JUL	15.400	.	13.000	16.300	16.900	.	.
AUG	15.900	.	17.600	18.300	17.700	.	.
SEP	14.600	.	18.700	15.800	18.300	.	.
OCT	14.300	.	18.200	18.000	17.800	.	.
NOV	15.200	.	17.000	.	17.200	.	.
DEC	15.000	.	17.400	.	.	17.600	17.200

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
COLOUR (HZU)			DET'N LIMIT = 0.5	GUIDELINE = 5 (A3)			
JAN	.	2.000	.500	.500 <T	.500 <T	.	.
FEB	.	.500 <T	.500 <T	1.000 <T	.500 <T	.	.
MAR	.	1.000 <T	.500 <T	BDL	BDL	.	.
APR	.	1.500 <T	.500 <T	.500 <T	BDL	.	.
MAY	.	1.000 <T	BDL	BDL	BDL	.	.
JUN	.	1.000 <T	BDL	BDL	BDL	.	.
JUL	1.000 <T	.	BDL	BDL	BDL	.	.
AUG	2.500	.	.500 <T	.500 <T	BDL	.	.
SEP	.500 <T	.	.500 <T	.500 <T	.500 <T	.	.
OCT	2.000 <T	.	1.000 <T	1.000 <T	.500 <T	.	.
NOV	1.000 <T	.	BDL	.	.500 <T	.	.
DEC	4.500	.	1.000 <T	.	.	1.000 <T	1.000 <T
CONDUCTIVITY (UMHO/CM)			DET'N LIMIT = 1.	GUIDELINE = 400 (F2)			
JAN	.	306	321	324	324	.	.
FEB	.	297	310	325	320	.	.
MAR	.	299	307	316	316	.	.
APR	.	295	309	318	316	.	.
MAY	.	289	296	311	309	.	.
JUN	.	285	296	308	308	.	.
JUL	289	.	298	307	306	.	.
AUG	292	.	301	312	311	.	.
SEP	281	.	298	308	307	.	.
OCT	289	.	320	331	329	.	.
NOV	296	.	311	.	317	.	.
DEC	298	.	311	.	.	315	317
DISS ORG CARBON (MG/L)			DET'N LIMIT = .100	GUIDELINE = 5.0 (A3)			
JAN	.	1.900	1.500	1.400	1.400	.	.
FEB	.	1.700	1.400	1.700	1.600	.	.
MAR	.	1.800	1.400	1.500	1.400	.	.
APR	.	2.000	1.700	1.700	1.500	.	.
MAY	.	2.000	1.700	1.700	1.700	.	.
JUN	.	1.400	2.000	1.700	1.700	.	.
JUL	2.300	.	1.500	1.500	1.400	.	.
AUG	2.300	.	1.700	1.600	1.600	.	.
SEP	1.900	.	1.600	1.600	1.600	.	.
OCT	2.100	.	1.600	1.500	1.500	.	.
NOV	2.100	.	1.600	.	1.700	.	.
DEC	1.900	.	1.600	.	.	1.500	1.600

TABLE 5

DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
FLUORIDE (MG/L)			DET'N LIMIT = 0.01	GUIDELINE = 2.4 (A1)			
JAN	.	.120	.100	.100	.100	.	.
FEB	.	.120	.120	.100	.100	.	.
MAR	.	.120	.120	.100	.100	.	.
APR	.	.120	.100	.120	.100	.	.
MAY	.	.120	.100	.100	.100	.	.
JUN	.	.120	.020 <T	.080	.080	.	.
JUL	.120	.	.160	.120	.120	.	.
AUG	.140	.	.120	.120	.120	.	.
SEP	.100	.	.100	.100	.100	.	.
OCT	.120	.	.120	.100	.120	.	.
NOV	.140	.	.120	.	.100	.	.
DEC	.120	.	.100	.	.	.100	.100
HARDNESS (MG/L)			DET'N LIMIT = 0.5	GUIDELINE = 80-100 (A4)			
JAN	.	139.000	141.000	144.000	145.000	.	.
FEB	.	131.000	131.600	143.000	141.000	.	.
MAR	.	137.600	134.100	136.000	137.000	.	.
APR	.	130.000	132.000	137.000	136.000	.	.
MAY	.	126.400	125.200	132.000	132.600	.	.
JUN	.	123.400	127.000	132.000	132.000	.	.
JUL	130.000	.	131.000	135.000	133.000	.	.
AUG	130.300	.	125.600	132.900	133.800	.	.
SEP	125.000	.	127.000	129.000	132.000	.	.
OCT	127.000	.	132.000	138.000	138.000	.	.
NOV	126.100	.	132.000	.	138.000	.	.
DEC	131.700	.	129.400	.	.	135.800	135.700
IONCAL (OMNSLESS)			DET'N LIMIT = N/A	GUIDELINE = N/A			
JAN	.	3.262	3.439	2.988	3.583	.	.
FEB	.	1.076	4.513	1.494	1.673	.	.
MAR	.	3.088	2.808	3.422	.090	.	.
APR	.	.416	.675	.912	.663	.	.
MAY	.	.388	1.263	1.962	1.126	.	.
JUN	.	1.741	.714	1.467	.942	.	.
JUL	.376	.	5.290	1.200	.153	.	.
AUG	2.675	.	.371	.831	2.296	.	.
SEP	1.310	.	1.301	.837	1.183	.	.
OCT	.655	.	.887	.001	.886	.	.
NOV	2.811	.	.184	.	2.618	.	.
DEC	2.982	.	.034	.	.	.359	1.114

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
LANGELIERS INDEX (DMNSLESS)			DET'N LIMIT = N/A	GUIDELINE = N/A			
JAN	.	.538	.457	.379	.393	.	.
FEB	.	.492	.193	.501	.461	.	.
MAR	.	.500	.300	.374	.414	.	.
APR	.	.507	.409	.495	.478	.	.
MAY	.	.473	.236	.309	.341	.	.
JUN	.	.419	.359	.446	.426	.	.
JUL	.470	.	.377	.490	.401	.	.
AUG	.395	.	.447	.507	.511	.	.
SEP	.404	.	.360	.467	.488	.	.
OCT	.437	.	.527	.608	.591	.	.
NOV	.473	.	.408	.	.459	.	.
DEC	.416	.	.302	.	.	.379	.384
MAGNESIUM (MG/L)			DET'N LIMIT = 0.1	GUIDELINE = 30 (F2)			
JAN	.	9.300	9.400	9.400	9.500	.	.
FEB	.	8.600	8.550	8.800	8.900	.	.
MAR	.	8.600	8.400	8.750	8.550	.	.
APR	.	8.600	8.600	8.500	8.600	.	.
MAY	.	8.450	8.450	8.500	8.450	.	.
JUN	.	8.450	8.500	8.200	8.300	.	.
JUL	9.000	.	9.100	9.000	8.500	.	.
AUG	9.000	.	9.050	8.600	9.000	.	.
SEP	8.400	.	8.700	8.100	8.100	.	.
OCT	8.700	.	9.000	8.800	9.000	.	.
NOV	8.300	.	8.900	.	8.700	.	.
DEC	9.000	.	8.750	.	.	8.950	8.900
SODIUM (MG/L)			DET'N LIMIT = 0.20	GUIDELINE = 200 (A4)			
JAN	.	10.200	11.800	11.200	11.200	.	.
FEB	.	8.000	10.100	10.200	10.000	.	.
MAR	.	9.200	10.300	9.900	10.000	.	.
APR	.	8.200	9.000	9.400	9.200	.	.
MAY	.	8.400	9.400	9.600	9.400	.	.
JUN	.	8.700	9.200	9.600	9.600	.	.
JUL	8.400	.	9.000	9.400	10.000	.	.
AUG	9.100	.	10.600	10.900	10.800	.	.
SEP	8.200	.	10.600	10.600	10.800	.	.
OCT	8.200	.	12.000	11.200	11.600	.	.
NOV	8.300	.	10.000	.	10.400	.	.
DEC	9.900	.	11.200	.	.	11.200	10.500

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
AMMONIUM TOTAL (MG/L)		DET'N LIMIT = 0.002		GUIDELINE = 0.05 (F2)			
JAN	.	BDL	BDL	BDL	.002 <T	.	.
FEB	.	.002 <T	BDL	BDL	BDL	.	.
MAR	.	BDL	BDL	BDL	BDL	.	.
APR	.	BDL	BDL	.006 <T	.012	.	.
MAY	.	.002 <T	BDL	BDL	BDL	.	.
JUN	.	BDL	BDL	BDL	BDL	.	.
JUL	.024	.	BDL	BDL	BDL	.	.
AUG	.100	.	BDL	.006 <T	.002 <T	.	.
SEP	BDL	.	BDL	.004 <T	BDL	.	.
OCT	.018	.	BDL	BDL	BDL	.	.
NOV	.002 <T	.	BDL	.	BDL	.	.
DEC	.022	.	BDL	.	.	.002 <T	.014
NITRITE (MG/L)		DET'N LIMIT = 0.001		GUIDELINE = 1 (A1)			
JAN	.	.004 <T	.002 <T	.003 <T	.002 <T	.	.
FEB	.	.003 <T	BDL	.004 <T	.005	.	.
MAR	.	.003 <T	BDL	.011	.006	.	.
APR	.	.002 <T	.001 <T	.003 <T	.002 <T	.	.
MAY	.	.005	.001 <T	.003 <T	.004 <T	.	.
JUN	.	.004 <T	.005	.008	.007	.	.
JUL	.010	.	BDL	.005	.009	.	.
AUG	.006	.	BDL	.001 <T	BDL	.	.
SEP	.055	.	.001 <T	.003 <T	.010	.	.
OCT	.003 <T	.	BDL	BDL	BDL	.	.
NOV	.003 <T	.	BDL	.	BDL	.	.
DEC	.007	.	BDL	.	.	.004 <T	.004 <T
TOTAL NITRATES (MG/L)		DET'N LIMIT = 0.005		GUIDELINE = 10 (A1)			
JAN	.	.280	.300	.220	.225	.	.
FEB	.	.280	.290	.330	.335	.	.
MAR	.	.280	.310	.365	.360	.	.
APR	.	.210	.265	.270	.275	.	.
MAY	.	.230	.320	.350	.345	.	.
JUN	.	.210	.215	.240	.245	.	.
JUL	.195	.	.200	.185	.205	.	.
AUG	.280	.	.155	.190	.185	.	.
SEP	.230	.	.180	.175	.170	.	.
OCT	.190	.	.195	.165	.165	.	.
NOV	.175	.	.215	.	.215	.	.
DEC	.230	.	.245	.	.	.235	.245

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
NITROGEN TOT KJELD (MG/L)			DET'N LIMIT = 0.02	GUIDELINE = N/A			
JAN	.	.270	.170	.250	.160	.	.
FEB	.	.230	.110	.210	.170	.	.
MAR	.	.230	.150	.180	.170	.	.
APR	.	.220	.160	.210	.160	.	.
MAY	.	.210	.150	.160	.140	.	.
JUN	.	.240	.130	.140	.140	.	.
JUL	.440	.	.140	.170	.140	.	.
AUG	.550	.	.130	.140	.150	.	.
SEP	.250	.	.110	.150	.120	.	.
OCT	.250	.	.140	.130	.120	.	.
NOV	.550	.	.180	.	.150	.	.
DEC	.220	.	.090 <T	.	.	.090 <T	.090 <T
PH (DMNSLESS)			DET'N LIMIT = N/A	GUIDELINE = 6.5-8.5(A4)			
JAN	.	8.350	8.290	8.180	8.200	.	.
FEB	.	8.340	8.060	8.300	8.280	.	.
MAR	.	8.310	8.160	8.220	8.250	.	.
APR	.	8.360	8.280	8.330	8.320	.	.
MAY	.	8.350	8.150	8.170	8.200	.	.
JUN	.	8.310	8.270	8.310	8.290	.	.
JUL	8.340	.	8.280	8.350	8.270	.	.
AUG	8.270	.	8.370	8.370	8.380	.	.
SEP	8.300	.	8.280	8.340	8.350	.	.
OCT	8.320	.	8.410	8.430	8.420	.	.
NOV	8.340	.	8.280	.	8.290	.	.
DEC	8.270	.	8.190	.	.	8.220	8.230
PHOSPHORUS FIL REACT (MG/L)			DET'N LIMIT = 0.0005	GUIDELINE = N/A			
JAN	.	.001 <T	BDL	.	.	.	.
FEB	.	.003	BDL	.	.	.	.
MAR	.	.001 <T	BDL	.	.	.	.
APR	.	BDL	BDL	.	.	.	.
MAY	.	BDL	BDL	.	.	.	.
JUN	.	.000 <T	BDL	.	.	.	.
JUL	BDL	.	BDL	.	.	.	.
AUG	BDL	.	.000 <T	.	.	.	.
SEP	.001 <T	.	BDL	.	.	.	.
OCT	.000 <T	.	.001 <T	.	.	.	.
NOV	.001 <T	.	.001 <T	.	.	.	.
DEC	.001 <T	.	BDL	.	.	.	.

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
PHOSPHORUS TOTAL (MG/L)			DET'N LIMIT = 0.002	GUIDELINE = .40 (F2)			
JAN	.	.013	.002 <T	.	.	.	.
FEB	.	.019	.002 <T	.	.	.	.
MAR	.	.011	BDL	.	.	.	.
APR	.	.009 <T	BDL	.	.	.	.
MAY	.	.008 <T	.002 <T	.	.	.	.
JUN	.	.008 <T	BDL	.	.	.	.
JUL	.012	.	BDL	.	.	.	.
AUG	.015	.	.003 <T	.	.	.	.
SEP	.011	.	.002 <T	.	.	.	.
OCT	.008 <T	.	.003 <T	.	.	.	.
NOV	.074	.	.003 <T	.	.	.	.
DEC	.019	.	.003 <T	.	.	.	.
SULPHATE (MG/L)			DET'N LIMIT = .200	GUIDELINE = 500 (A3)			
JAN	.	25.290	34.110	33.770	33.770	.	.
FEB	.	24.880	36.130	33.710	33.070	.	.
MAR	.	25.240	33.190	32.890	33.300	.	.
APR	.	23.560	31.860	33.770	33.490	.	.
MAY	.	24.240	30.000	31.320	31.300	.	.
JUN	.	24.150	31.350	32.170	32.020	.	.
JUL	24.600	.	31.590	32.040	32.100	.	.
AUG	24.300	.	29.830	29.980	30.300	.	.
SEP	23.670	.	29.880	30.170	30.120	.	.
OCT	23.830	.	32.130	31.360	31.600	.	.
NOV	23.910	.	30.010	.	29.480	.	.
DEC	24.480	.	31.140	.	.	31.570	30.720
TURBIDITY (FTU)			DET'N LIMIT = 0.05	GUIDELINE = 1 (A1)			
JAN	.	4.600	.190 <T	.320	.150 <T	.	.
FEB	.	7.000	.400	.540	.430	.	.
MAR	.	5.200	.590	.870	.950	.	.
APR	.	1.920	.220	.400	.460	.	.
MAY	.	1.870	.340	.490	.340	.	.
JUN	.	3.900	.210 <T	.400	.320	.	.
JUL	1.200	.	.370	.350	.210 <T	.	.
AUG	1.500	.	.270	.330	.160 <T	.	.
SEP	1.600	.	.270	.320	.270	.	.
OCT	2.300	.	.170 <T	.230 <T	.250	.	.
NOV	1.640	.	.310	.	.270	.	.
DEC	5.500	.	.440	.	.	1.690	.460

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
METALS							
ALUMINUM (UG/L)			DET'N LIMIT = 0.10	GUIDELINE = 100 (A4)			
JAN	.	40.000	38.000	44.000	32.000	.	.
FEB	.	85.000	62.000	43.000	29.000	.	.
MAR	.	42.000	45.000	38.000	37.000	.	.
APR	.	23.000	51.000	50.000	40.000	.	.
MAY	.	35.000	82.000	70.000	63.000	.	.
JUN	.	57.000	66.000	61.000	61.000	.	.
JUL	18.000	.	85.000	68.000	66.000	.	.
AUG	19.000	.	190.000	170.000	160.000	.	.
SEP	17.000	.	190.000	180.000	190.000	.	.
OCT	31.000	.	120.000	130.000	140.000	.	.
NOV	20.000	.	110.000	.	99.000	.	.
DEC	69.000	.	71.000	.	.	59.000	42.000
ARSENIC (UG/L)			DET'N LIMIT = 0.10	GUIDELINE = 25 (A1)			
JAN	.	.780 <T	.230 <T	.210 <T	.230 <T	.	.
FEB	.	.710 <T	.460 <T	.320 <T	.270 <T	.	.
MAR	.	.700 <T	.170 <T	.240 <T	.340 <T	.	.
APR	.	.800 <T	.270 <T	.210 <T	.240 <T	.	.
MAY	.	.590 <T	.310 <T	.250 <T	.400 <T	.	.
JUN	.	.610 <T	BDL	.230 <T	.120 <T	.	.
JUL	.530 <T	.	BDL	.230 <T	.160 <T	.	.
AUG	.680 <T	.	.300 <T	.260 <T	.240 <T	.	.
SEP	.780 <T	.	.190 <T	.230 <T	.180 <T	.	.
OCT	.820 <T	.	.370 <T	.490 <T	.400 <T	.	.
NOV	.550 <T	.	BDL	.	.130 <T	.	.
DEC	.640 <T	.	BDL	.	.	BDL	BDL
BARIUM (UG/L)			DET'N LIMIT = 0.05	GUIDELINE = 1000 (A2)			
JAN	.	24.000	22.000	27.000	24.000	.	.
FEB	.	23.000	24.000	27.000	22.000	.	.
MAR	.	22.000	21.000	21.000	21.000	.	.
APR	.	23.000	22.000	26.000	21.000	.	.
MAY	.	21.000	21.000	22.000	20.000	.	.
JUN	.	21.000	19.000	20.000	20.000	.	.
JUL	20.000	.	20.000	22.000	21.000	.	.
AUG	21.000	.	21.000	21.000	20.000	.	.
SEP	21.000	.	21.000	21.000	21.000	.	.
OCT	25.000	.	24.000	25.000	25.000	.	.
NOV	20.000	.	20.000	.	20.000	.	.
DEC	23.000	.	21.000	.	.	21.000	21.000

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
BORON (UG/L)			DET'N LIMIT = 2.00	GUIDELINE = 5000 (A1)			
JAN	.	26.000	28.000	31.000	25.000	.	.
FEB	.	31.000	290.000	26.000	31.000	.	.
MAR	.	22.000	31.000	32.000	31.000	.	.
APR	.	26.000	26.000	41.000	40.000	.	.
MAY	.	65.000	68.000	68.000	69.000	.	.
JUN	.	55.000	46.000	56.000	54.000	.	.
JUL	24.000	.	24.000	24.000	23.000	.	.
AUG	37.000	.	33.000	35.000	33.000	.	.
SEP	31.000	.	27.000	31.000	29.000	.	.
OCT	24.000	.	24.000	25.000	25.000	.	.
NOV	22.000	.	27.000	.	25.000	.	.
DEC	28.000	.	24.000	.	.	24.000	23.000
BERYLLIUM (UG/L)			DET'N LIMIT = 0.05	GUIDELINE = 6800 (D4)			
JAN	.	BDL	BDL	BDL	BDL	.	.
FEB	.	BDL	BDL	BDL	BDL	.	.
MAR	.	BDL	BDL	BDL	BDL	.	.
APR	.	BDL	BDL	BDL	BDL	.	.
MAY	.	.060 <T	BDL	.090 <T	.070 <T	.	.
JUN	.	.060 <T	.060 <T	BDL	BDL	.	.
JUL	BDL	.	BDL	BDL	BDL	.	.
AUG	BDL	.	BDL	BDL	BDL	.	.
SEP	BDL	.	BDL	BDL	BDL	.	.
OCT	BDL	.	BDL	BDL	BDL	.	.
NOV	BDL	.	BDL	.	BDL	.	.
DEC	BDL	.	BDL	.	.	BDL	BDL
CADMIUM (UG/L)			DET'N LIMIT = 0.05	GUIDELINE = 5 (A1)			
JAN	.	BDL	.140 <T	BDL	BDL	.	.
FEB	.	BDL	BDL	BDL	BDL	.	.
MAR	.	BDL	BDL	BDL	BDL	.	.
APR	.	BDL	BDL	BDL	BDL	.	.
MAY	.	BDL	BDL	BDL	BDL	.	.
JUN	.	BDL	BDL	.130 <T	BDL	.	.
JUL	BDL	.	.060 <T	BDL	BDL	.	.
AUG	BDL	.	BDL	BDL	BDL	.	.
SEP	BDL	.	BDL	BDL	BDL	.	.
OCT	BDL	.	BDL	BDL	BDL	.	.
NOV	BDL	.	BDL	.	BDL	.	.
DEC	.080 <T	.	BDL	.	.	BDL	BDL

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
COBALT (UG/L)			DET'N LIMIT = 0.02	GUIDELINE = N/A			
JAN	.	.230 <T	BDL	.030 <T	BDL	.	.
FEB	.	.140 <T	.220 <T	.120 <T	.080 <T	.	.
MAR	.	.140 <T	.150 <T	.090 <T	.130 <T	.	.
APR	.	.110 <T	.140 <T	.090 <T	.080 <T	.	.
MAY	.	.130 <T	.140 <T	.110 <T	.130 <T	.	.
JUN	.	BDL	.100 <T	.070 <T	.060 <T	.	.
JUL	.230 <T	.	.130 <T	.150 <T	.150 <T	.	.
AUG	.120 <T	.	.090 <T	.050 <T	BDL	.	.
SEP	.040 <T	.	.040 <T	.060 <T	.040 <T	.	.
OCT	.110 <T	.	.110 <T	.100 <T	.070 <T	.	.
NOV	.090 <T	.	.040 <T	.	BDL	.	.
DEC	.130 <T	.	.100 <T	.	.	.130 <T	.090 <T
CHROMIUM (UG/L)			DET'N LIMIT = 0.50	GUIDELINE = 50 (A1)			
JAN	.	BDL	BDL	.540 <T	BDL	.	.
FEB	.	1.100 <T	3.900 <T	BDL	.950 <T	.	.
MAR	.	BDL	1.600 <T	1.300 <T	1.200 <T	.	.
APR	.	BDL	.630 <T	3.200 <T	2.800 <T	.	.
MAY	.	3.000 <T	3.200 <T	3.200 <T	3.400 <T	.	.
JUN	.	2.100 <T	2.100 <T	2.300 <T	2.400 <T	.	.
JUL	1.200 <T	.	1.400 <T	1.400 <T	1.700 <T	.	.
AUG	2.600 <T	.	2.200 <T	2.300 <T	2.300 <T	.	.
SEP	2.000 <T	.	1.800 <T	2.000 <T	1.900 <T	.	.
OCT	BDL	.	.660 <T	.570 <T	.560 <T	.	.
NOV	.930 <T	.	2.300 <T	.	2.200 <T	.	.
DEC	BDL	.	BDL	.	.	.610 <T	.940 <T
COPPER (UG/L)			DET'N LIMIT = 0.50	GUIDELINE = 1000 (A3)			
JAN	.	2.200 <T	1.200 <T	370.000	16.000	.	.
FEB	.	3.300 <T	1.000 <T	110.000	17.000	.	.
MAR	.	3.100 <T	1.100 <T	32.000	16.000	.	.
APR	.	3.200 <T	1.300 <T	59.000	13.000	.	.
MAY	.	1.500 <T	.940 <T	270.000	35.000	.	.
JUN	.	2.700 <T	1.500 <T	110.000	26.000	.	.
JUL	5.000 <T	.	1.300 <T	190.000	44.000	.	.
AUG	6.500	.	1.300 <T	33.000	21.000	.	.
SEP	3.000 <T	.	1.500 <T	130.000	24.000	.	.
OCT	3.600 <T	.	1.300 <T	14.000	11.000	.	.
NOV	1.000 <T	.	1.000 <T	.	9.800	.	.
DEC	2.500 <T	.	1.200 <T	.	.	50.000	3.400 <T

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
IRON (UG/L)			DET'N LIMIT = 6.00	GUIDELINE = 300 (A3)			
JAN	.	58.000 <T	6.100 <T	7.900 <T	9.100 <T	.	.
FEB	.	100.000	BDL	BDL	BDL	.	.
MAR	.	61.000	BDL	6.700 <T	BDL	.	.
APR	.	31.000 <T	BDL	BDL	BDL	.	.
MAY	.	38.000 <T	BDL	BDL	7.200 <T	.	.
JUN	.	61.000	BDL	BDL	BDL	.	.
JUL	31.000 <T	.	BDL	BDL	10.000 <T	.	.
AUG	30.000 <T	.	BDL	BDL	15.000 <T	.	.
SEP	27.000 <T	.	BDL	BDL	BDL	.	.
OCT	60.000 <T	.	BDL	BDL	BDL	.	.
NOV	9.600 <T	.	BDL	.	6.200 <T	.	.
DEC	120.000	.	BDL	.	.	70.000	BDL
MERCURY (UG/L)			DET'N LIMIT = 0.02	GUIDELINE = 1 (A1)			
JAN	.	.020 <T	.030 <T	.	.	.	.
FEB	.	BDL	BDL	.	.	.	.
MAR	.	BDL	BDL	.	.	.	.
APR	.	BDL	BDL	.	.	.	.
MAY	.	BDL	BDL	.	.	.	.
JUN	.	BDL	BDL	.	.	.	.
JUL	BDL	.	BDL	.	.	.	.
AUG	.	.	BDL	.	.	.	.
SEP	BDL	.	BDL	.	.	.	.
OCT	BDL	.	BDL	.	.	.	.
NOV	.050 <T	.	.100 <T	.	.	.	.
DEC	BDL	.	BDL	.	.	.	.
MANGANESE (UG/L)			DET'N LIMIT = 0.05	GUIDELINE = 50 (A3)			
JAN	.	4.400	2.700	1.100	.670	.	.
FEB	.	5.600	1.200	1.300	.780	.	.
MAR	.	3.900	1.800	.750	.570	.	.
APR	.	2.700	1.800	.550	.480 <T	.	.
MAY	.	3.100	1.600	.870	.560	.	.
JUN	.	5.100	1.000	.500 <T	.380 <T	.	.
JUL	4.200	.	.810	.590	.440 <T	.	.
AUG	4.200	.	.730	.300 <T	.190 <T	.	.
SEP	3.800	.	.720	.490 <T	.420 <T	.	.
OCT	4.800	.	.270 <T	.470 <T	.460 <T	.	.
NOV	2.000	.	.260 <T	.	.940	.	.
DEC	6.500	.	.970	.	.	1.700	.110 <T

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
MOLYBDENUM (UG/L)			DET'N LIMIT = 0.05	GUIDELINE = N/A			
JAN	.	1.200	1.300	1.400	1.500	.	.
FEB	.	1.200	1.300	1.500	1.400	.	.
MAR	.	.930	1.200	1.600	1.500	.	.
APR	.	1.500	1.500	1.300	1.300	.	.
MAY	.	1.400	1.300	1.300	1.100	.	.
JUN	.	.920	1.200	1.200	1.300	.	.
JUL	1.100	.	1.100	1.200	1.200	.	.
AUG	1.000	.	1.300	1.500	1.300	.	.
SEP	1.400	.	1.300	1.400	1.300	.	.
OCT	1.300	.	1.400	1.400	1.400	.	.
NOV	1.100	.	1.200	.	1.200	.	.
DEC	1.800	.	1.600	.	.	.920	1.400
NICKEL (UG/L)			DET'N LIMIT = 0.20	GUIDELINE = 350 (D3)			
JAN	.	BDL	BDL	BDL	BDL	.	.
FEB	.	BDL	BDL	.400 <T	BDL	.	.
MAR	.	.900 <T	.720 <T	BDL	BDL	.	.
APR	.	BDL	.640 <T	1.300 <T	1.500 <T	.	.
MAY	.	.700 <T	.980 <T	.950 <T	1.200 <T	.	.
JUN	.	.730 <T	.420 <T	.690 <T	.520 <T	.	.
JUL	1.600 <T	.	1.300 <T	1.300 <T	1.200 <T	.	.
AUG	1.400 <T	.	.990 <T	1.200 <T	1.000 <T	.	.
SEP	.370 <T	.	.320 <T	BDL	BDL	.	.
OCT	2.700	.	2.400	2.300	2.100	.	.
NOV	BDL	.	BDL	.	.390 <T	.	.
DEC	.840 <T	.	.890 <T	.	.	1.500 <T	.820 <T
LEAD (UG/L)			DET'N LIMIT = 0.05	GUIDELINE = 10. (A1)			
JAN	.	.150 <T	BDL	5.800	.190 <T	.	.
FEB	.	.250 <T	.160 <T	.730	.130 <T	.	.
MAR	.	.100 <T	BDL	.520	.180 <T	.	.
APR	.	.060 <T	BDL	.860	.200 <T	.	.
MAY	.	.130 <T	.100 <T	4.800	.780	.	.
JUN	.	.130 <T	BDL	3.200	.880	.	.
JUL	.490 <T	.	.060 <T	4.000	1.100	.	.
AUG	3.200	.	.120 <T	.770	.420 <T	.	.
SEP	.210 <T	.	.070 <T	8.300	1.100	.	.
OCT	.160 <T	.	.060 <T	.440 <T	.340 <T	.	.
NOV	BDL	.	BDL	.	.190 <T	.	.
DEC	.210 <T	.	BDL	.	.	2.800	.090 <T

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
ANTIMONY (UG/L)			DET'N LIMIT = 0.05	GUIDELINE = 146 (D4)			
JAN	.	1.000	.330 <T	.590	.430 <T	.	.
FEB	.	.480 <T	.980	.650	.680	.	.
MAR	.	.420 <T	.480 <T	.600	.520	.	.
APR	.	.450 <T	.510	.550	.640	.	.
MAY	.	.500 <T	.390 <T	.620	.420 <T	.	.
JUN	.	.380 <T	.450 <T	.510	.520	.	.
JUL	.700	.	.570	.700	.720	.	.
AUG	.630	.	.610	.730	.600	.	.
SEP	.540	.	.520	.560	.490 <T	.	.
OCT	.480 <T	.	.380 <T	.580	.550	.	.
NOV	.570	.	.500 <T	.	.530	.	.
DEC	.530	.	.560	.	.	.670	.560
SELENIUM (UG/L)			DET'N LIMIT = 1.00	GUIDELINE = 10 (A1)			
JAN	.	BDL	1.700 <T	BDL	1.500 <T	.	.
FEB	.	BDL	BDL	BDL	BDL	.	.
MAR	.	1.100 <T	BDL	2.100 <T	BDL	.	.
APR	.	BDL	BDL	BDL	1.900 <T	.	.
MAY	.	BDL	1.300 <T	1.500 <T	1.500 <T	.	.
JUN	.	BDL	BDL	2.600 <T	1.800 <T	.	.
JUL	BDL	.	1.700 <T	2.000 <T	1.800 <T	.	.
AUG	1.300 <T	.	1.800 <T	2.200 <T	1.500 <T	.	.
SEP	BDL	.	1.100 <T	1.900 <T	1.600 <T	.	.
OCT	BDL	.	BDL	BDL	BDL	.	.
NOV	BDL	.	1.100 <T	.	1.700 <T	.	.
DEC	1.200 <T	.	1.100 <T	.	.	1.300 <T	1.300 <T
STRONTIUM (UG/L)			DET'N LIMIT = 0.10	GUIDELINE = N/A			
JAN	.	190.000	200.000	200.000	200.000	.	.
FEB	.	190.000	420.000	200.000	190.000	.	.
MAR	.	180.000	200.000	250.000	250.000	.	.
APR	.	200.000	200.000	200.000	200.000	.	.
MAY	.	180.000	180.000	190.000	190.000	.	.
JUN	.	170.000	160.000	160.000	160.000	.	.
JUL	160.000	.	160.000	170.000	170.000	.	.
AUG	160.000	.	160.000	170.000	170.000	.	.
SEP	160.000	.	170.000	180.000	180.000	.	.
OCT	210.000	.	200.000	200.000	200.000	.	.
NOV	170.000	.	200.000	.	170.000	.	.
DEC	180.000	.	210.000	.	.	190.000	190.000

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
TITANIUM (UG/L)			DET'N LIMIT = 0.50	GUIDELINE = N/A			
JAN	.	4.700 <T	3.200 <T	3.800 <T	3.700 <T	.	.
FEB	.	4.700 <T	11.000	8.700	8.800	.	.
MAR	.	4.500 <T	3.100 <T	4.400 <T	4.300 <T	.	.
APR	.	4.200 <T	2.900 <T	3.300 <T	2.900 <T	.	.
MAY	.	8.200	6.700	7.500	7.000	.	.
JUN	.	7.500	5.700	6.500	6.500	.	.
JUL	3.800 <T	.	3.200 <T	3.900 <T	4.000 <T	.	.
AUG	3.200 <T	.	2.700 <T	2.500 <T	2.500 <T	.	.
SEP	3.200 <T	.	2.500 <T	3.100 <T	2.800 <T	.	.
OCT	2.900 <T	.	1.700 <T	1.700 <T	1.700 <T	.	.
NOV	2.900 <T	.	2.000 <T	.	2.100 <T	.	.
DEC	5.500	.	2.400 <T	.	.	2.700 <T	2.500 <T
THALLIUM (UG/L)			DET'N LIMIT = 0.05	GUIDELINE = 13 (D4)			
JAN	.	.060 <T	BDL	.060 <T	BDL	.	.
FEB	.	BDL	.100 <T	BDL	BDL	.	.
MAR	.	BDL	BDL	BDL	BDL	.	.
APR	.	BDL	BDL	BDL	BDL	.	.
MAY	.	BDL	BDL	BDL	BDL	.	.
JUN	.	BDL	BDL	BDL	BDL	.	.
JUL	BDL	.	BDL	BDL	BDL	.	.
AUG	BDL	.	BDL	BDL	BDL	.	.
SEP	BDL	.	BDL	BDL	BDL	.	.
OCT	BDL	.	BDL	BDL	BDL	.	.
NOV	BDL	.	BDL	.	BDL	.	.
DEC	BDL	.	BDL	.	.	BDL	BDL
URANIUM (UG/L)			DET'N LIMIT = 0.05	GUIDELINE = 100 (A1)			
JAN	.	.300 <T	.170 <T	.100 <T	.150 <T	.	.
FEB	.	.290 <T	.130 <T	.180 <T	.210 <T	.	.
MAR	.	.290 <T	.200 <T	.180 <T	.140 <T	.	.
APR	.	.280 <T	.160 <T	.140 <T	.190 <T	.	.
MAY	.	.330 <T	.210 <T	.150 <T	.150 <T	.	.
JUN	.	.380 <T	.150 <T	.160 <T	.150 <T	.	.
JUL	.310 <T	.	.100 <T	.130 <T	.110 <T	.	.
AUG	.330 <T	.	.230 <T	.170 <T	.160 <T	.	.
SEP	.330 <T	.	.120 <T	.080 <T	.150 <T	.	.
OCT	.410 <T	.	.200 <T	.210 <T	.200 <T	.	.
NOV	.320 <T	.	.260 <T	.	.190 <T	.	.
DEC	.340 <T	.	.220 <T	.	.	.160 <T	.250 <T

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
VANADIUM (UG/L)			DET'N LIMIT = 0.05	GUIDELINE = N/A			
JAN	.	.290 <T	.350 <T	.370 <T	.240 <T	.	.
FEB	.	.390 <T	.540	.400 <T	.310 <T	.	.
MAR	.	.320 <T	.560	.330 <T	.400 <T	.	.
APR	.	.390 <T	.650	.420 <T	.340 <T	.	.
MAY	.	.220 <T	.570	.420 <T	.330 <T	.	.
JUN	.	.240 <T	.630	.330 <T	.270 <T	.	.
JUL	.240 <T	.	.710	.460 <T	.500 <T	.	.
AUG	.220 <T	.	.590	.560	.510	.	.
SEP	.360 <T	.	.640	.500 <T	.580	.	.
OCT	.330 <T	.	.880	.680	.650	.	.
NOV	.280 <T	.	.630	.	.460 <T	.	.
DEC	.640	.	.490 <T	.	.	.350 <T	.430 <T
ZINC (UG/L)			DET'N LIMIT = 0.20	GUIDELINE = 5000 (A3)			
JAN	.	2.300	1.500 <T	27.000	2.600	.	.
FEB	.	2.800	1.500 <T	7.600	2.500	.	.
MAR	.	2.700	1.700 <T	6.100	2.500	.	.
APR	.	2.500	1.700 <T	6.400	2.800	.	.
MAY	.	1.700 <T	1.400 <T	29.000	3.800	.	.
JUN	.	2.400	1.800 <T	20.000	3.400	.	.
JUL	7.300	.	1.900 <T	20.000	5.400	.	.
AUG	7.800	.	1.200 <T	2.900	1.700 <T	.	.
SEP	1.900 <T	.	1.500 <T	19.000	3.500	.	.
OCT	2.100	.	1.200 <T	2.300	1.600 <T	.	.
NOV	2.300	.	2.000 <T	.	2.400	.	.
DEC	4.300	.	2.500	.	.	39.000	1.700 <T

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
PAH							
PHENANTHRENE (NG/L)		DET'N LIMIT = 10.		GUIDELINE = N/A			
JAN	.	BDL	BDL	.	.	.	.
FEB	.	!QU	BDL	.	.	.	.
MAR	.	BDL	BDL	.	.	.	.
APR	.	BDL	BDL	.	.	.	.
MAY	.	BDL	!IS	.	.	.	.
JUN	.	BDL	BDL	.	.	.	.
JUL	BDL	.	BDL	.	.	.	.
AUG	230.000	.	BDL	.	!LA	.	.
SEP	BDL	.	BDL	.	.	.	.
OCT	BDL	.	BDL	.	.	.	.
NOV	BDL	.	BDL	.	.	.	.
DEC	BDL	.	BDL	.	.	.	.
BENZO(K) FLUORANTHENE (NG/L)		DET'N LIMIT = 1.		GUIDELINE = N/A			
JAN	.	BDL	BDL	.	.	.	.
FEB	.	!QU	BDL	.	.	.	.
MAR	.	BDL	BDL	.	.	.	.
APR	.	BDL	BDL	.	.	.	.
MAY	.	BDL	!IS	.	.	.	.
JUN	.	BDL	BDL	.	.	.	.
JUL	BDL	.	BDL	.	.	.	.
AUG	2.000 <T	.	BDL	.	!LA	.	.
SEP	BDL	.	BDL	.	.	.	.
OCT	BDL	.	BDL	.	.	.	.
NOV	BDL	.	BDL	.	.	.	.
DEC	BDL	.	BDL	.	.	.	.

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
PESTICIDES & PCB							
ALPHA BHC (NG/L)			DET'N LIMIT = 1.000	GUIDELINE = 700 (G)			
JAN	.	BDL	1.000 <T	.	BDL	.	.
FEB	.	IQU	BDL	.	BDL	.	.
MAR	.	1.000 <T	1.000 <T	.	1.000 <T	.	.
APR	.	1.000 <T	1.000 <T	.	2.000 <T	.	.
MAY	.	BDL	1.000 <T	.	1.000 <T	.	.
JUN	.	BDL	2.000 <T	.	2.000 <T	.	.
JUL	1.000 <T	.	1.000 <T	.	BDL	.	.
AUG	2.000 <T	.	1.000 <T	.	2.000 <T	.	.
SEP	BDL	.	2.000 <T	.	1.000 <T	.	.
OCT	1.000 <T	.	BDL	.	BDL	.	.
NOV	BDL	.	BDL	.	1.000 <T	.	.
DEC	ISM	.	BDL	.	.	.	BDL
LINDANE (NG/L)			DET'N LIMIT = 1.000	GUIDELINE = 4000 (A1)			
JAN	.	BDL	1.000 <T	.	BDL	.	.
FEB	.	IQU	BDL	.	BDL	.	.
MAR	.	BDL	BDL	.	BDL	.	.
APR	.	BDL	BDL	.	BDL	.	.
MAY	.	BDL	BDL	.	BDL	.	.
JUN	.	BDL	BDL	.	BDL	.	.
JUL	BDL	.	BDL	.	BDL	.	.
AUG	BDL	.	BDL	.	BDL	.	.
SEP	BDL	.	BDL	.	BDL	.	.
OCT	BDL	.	BDL	.	BDL	.	.
NOV	BDL	.	BDL	.	BDL	.	.
DEC	ISM	.	BDL	.	.	.	BDL
ATRAZINE (NG/L)			DET'N LIMIT = 50	GUIDELINE = 60000 (A2)			
JAN	.	BDL	BDL	.	.	.	.
FEB	.	BDL	INR	.	.	.	.
MAR	.	BDL	BDL	.	.	.	.
APR	.	60.000 <T	BDL	.	.	.	.
MAY	.	BDL	90.000 <T	.	.	.	.
JUN	.	BDL	BDL	.	.	.	.
JUL	BDL	.	60.000 <T	.	.	.	.
AUG	90.000 <T	.	BDL	.	.	.	.
SEP	80.000 <T	.	BDL	.	.	.	.
OCT	BDL	.	BDL	.	.	.	.
NOV	IIS	.	150.000 <T	.	.	.	.
DEC	BDL	.	BDL	.	.	.	.

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
PHENOLICS (UG/L)	PHENOLICS	DET'N LIMIT = .2		GUIDELINE = 2 (A4)			
JAN	.	.600 <T	.400 <T	.	.	.	.
FEB	.	BDL	BDL	.	.	.	.
MAR	.	.600 <T	.800 <T	.	.	.	.
APR	.	.600 <T	.800 <T	.	.	.	.
MAY	.	BDL	BDL	.	.	.	.
JUN	.	.600 <T	BDL	.	.	.	.
JUL	1.800	.	BDL	.	.	.	.
AUG	.400 <T	.	.600 <T	.	.	.	.
SEP	BDL	.	BDL	.	.	.	.
OCT	.400 <T	.	BDL	.	.	.	.
NOV	BDL	.	BDL	.	.	.	.
DEC	1.000 <T	.	.600 <T	.	.	.	.

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
VOLATILES							
BENZENE (UG/L)		DET'N LIMIT = 0.05		GUIDELINE = 5 (A1)			
JAN	.	BDL	BDL	.	BDL	.	.
FEB	.	BDL	BDL	.	BDL	.	.
MAR	.	.050 <T	.100 <T	.	BDL	.	.
APR	.	BDL	.150 <T	.	.100 <T	.	.
MAY	.	!IV	.150 <T	.	.100 <T	.	.
JUN	.	BDL	.100 <T	.	!LA	.	.
JUL	BDL	.	BDL	.	BDL	.	.
AUG	BDL	.	BDL	.	BDL	.	.
SEP	BDL	.	BDL	.	BDL	.	.
OCT	BDL	.	.050 <T	.	BDL	.	.
NOV	BDL	.	BDL	.	BDL	.	.
DEC	BDL	.	BDL	.	.	.	BDL
TOLUENE (UG/L)		DET'N LIMIT = 0.05		GUIDELINE = 24 (A3)			
JAN	.	.100 <T	.150 <T	.	.050 <T	.	.
FEB	.	BDL	BDL	.	BDL	.	.
MAR	.	BDL	.100 <T	.	BDL	.	.
APR	.	BDL	.100 <T	.	.050 <T	.	.
MAY	.	!IV	.150 <T	.	BDL	.	.
JUN	.	BDL	.100 <T	.	!LA	.	.
JUL	BDL	.	.100 <T	.	BDL	.	.
AUG	BDL	.	.100 <T	.	BDL	.	.
SEP	BDL	.	.050 <T	.	.050 <T	.	.
OCT	BDL	.	.100 <T	.	BDL	.	.
NOV	BDL	.	.050 <T	.	.050 <T	.	.
DEC	BDL	.	.100 <T	.	.	.	BDL
ETHYLBENZENE (UG/L)		DET'N LIMIT = 0.05		GUIDELINE = 2.4 (A3)			
JAN	.	BDL	BDL	.	BDL	.	.
FEB	.	BDL	BDL	.	BDL	.	.
MAR	.	.050 <T	.050 <T	.	.050 <T	.	.
APR	.	BDL	.200 <T	.	.250 <T	.	.
MAY	.	!IV	.100 <T	.	.100 <T	.	.
JUN	.	BDL	.050 <T	.	!LA	.	.
JUL	BDL	.	.100 <T	.	.150 <T	.	.
AUG	.050 <T	.	.150 <T	.	.100 <T	.	.
SEP	BDL	.	.150 <T	.	.050 <T	.	.
OCT	BDL	.	BDL	.	BDL	.	.
NOV	BDL	.	.200 <T	.	.100 <T	.	.
DEC	.050 <T	.	.100 <T	.	.	.	.050 <T

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
M-XYLENE (UG/L)			DET'N LIMIT = 0.10		GUIDELINE = 300 (A3*)		
JAN	.	BDL	.100 <T	.	BDL	.	.
FEB	.	BDL	BDL	.	BDL	.	.
MAR	.	BDL	BDL	.	BDL	.	.
APR	.	BDL	BDL	.	.300 <T	.	.
MAY	.	!IV	.100 <T	.	BDL	.	.
JUN	.	BDL	BDL	.	!LA	.	.
JUL	BDL	.	BDL	.	BDL	.	.
AUG	BDL	.	BDL	.	.100 <T	.	.
SEP	BDL	.	BDL	.	.200 <T	.	.
OCT	BDL	.	BDL	.	BDL	.	.
NOV	BDL	.	BDL	.	BDL	.	.
DEC	BDL	.	BDL	.	.	.	BDL
O-XYLENE (UG/L)			DET'N LIMIT = 0.05		GUIDELINE = 300 (A3*)		
JAN	.	BDL	BDL	.	.050 <T	.	.
FEB	.	BDL	BDL	.	BDL	.	.
MAR	.	BDL	BDL	.	BDL	.	.
APR	.	BDL	BDL	.	BDL	.	.
MAY	.	!IV	.050 <T	.	BDL	.	.
JUN	.	BDL	BDL	.	!LA	.	.
JUL	BDL	.	.050 <T	.	.050 <T	.	.
AUG	BDL	.	.100 <T	.	.150 <T	.	.
SEP	BDL	.	.050 <T	.	.150 <T	.	.
OCT	BDL	.	.050 <T	.	BDL	.	.
NOV	BDL	.	BDL	.	.050 <T	.	.
DEC	BDL	.	BDL	.	.	.	BDL
STYRENE (UG/L)			DET'N LIMIT = 0.05		GUIDELINE = 100 (D1)		
JAN	.	BDL	BDL	.	BDL	.	.
FEB	.	BDL	BDL	.	BDL	.	.
MAR	.	BDL	BDL	.	.150 <T	.	.
APR	.	BDL	.150 <T	.	.150 <T	.	.
MAY	.	!IV	.100 <T	.	.150 <T	.	.
JUN	.	BDL	BDL	.	!LA	.	.
JUL	BDL	.	.100 <T	.	.200 <T	.	.
AUG	.100 <T	.	BDL	.	.150 <T	.	.
SEP	BDL	.	BDL	.	.050 <T	.	.
OCT	.100 <T	.	BDL	.	BDL	.	.
NOV	.100 <T	.	BDL	.	.100 <T	.	.
DEC	.100 <T	.	BDL	.	.	.	.050 <T

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
CHLOROFORM (UG/L)			DET'N LIMIT = 0.10	GUIDELINE = 350 (A1+)			
JAN	.	BDL	15.000	.	16.600	.	.
FEB	.	BDL	6.400	.	16.400	.	.
MAR	.	BDL	15.400	.	18.500	.	.
APR	.	BDL	13.100	.	18.700	.	.
MAY	.	!IV	16.900	.	17.000	.	.
JUN	.	BDL	21.300	.	!LA	.	.
JUL	.300 <T	.	17.900	.	23.800	.	.
AUG	.300 <T	.	25.000	.	36.700	.	.
SEP	BDL	.	29.200	.	38.800	.	.
OCT	.300 <T	.	31.500	.	32.000	.	.
NOV	BDL	.	22.900	.	35.000	.	.
DEC	BDL	.	15.900	.	.	.	24.600
111, TRICHLOROETHANE (UG/L)			DET'N LIMIT = 0.02	GUIDELINE = 200 (D1)			
JAN	.	BDL	BDL	.	BDL	.	.
FEB	.	BDL	BDL	.	BDL	.	.
MAR	.	BDL	BDL	.	BDL	.	.
APR	.	BDL	BDL	.	BDL	.	.
MAY	.	!IV	BDL	.	BDL	.	.
JUN	.	BDL	BDL	.	!LA	.	.
JUL	BDL	.	BDL	.	BDL	.	.
AUG	BDL	.	BDL	.	BDL	.	.
SEP	BDL	.	BDL	.	BDL	.	.
OCT	BDL	.	BDL	.	BDL	.	.
NOV	BDL	.	BDL	.	BDL	.	.
DEC	BDL	.	.060 <T	.	.	.	BDL
DICHLOROBROMOMETHANE (UG/L)			DET'N LIMIT = 0.05	GUIDELINE = 350 (A1+)			
JAN	.	BDL	10.600	.	10.850	.	.
FEB	.	BDL	6.150	.	10.400	.	.
MAR	.	BDL	9.450	.	9.500	.	.
APR	.	BDL	10.000	.	10.300	.	.
MAY	.	!IV	7.900	.	9.800	.	.
JUN	.	BDL	10.700	.	!LA	.	.
JUL	.200 <T	.	10.300	.	12.000	.	.
AUG	.150 <T	.	11.700	.	14.900	.	.
SEP	BDL	.	11.400	.	14.350	.	.
OCT	.200 <T	.	11.100	.	13.800	.	.
NOV	BDL	.	11.000	.	13.600	.	.
DEC	BDL	.	9.000	.	.	.	11.700

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
CHLORODIBROMOMETHANE (UG/L)		**DET'N LIMIT = 0.10**		**GUIDELINE = 350 (A1+)**			
JAN	.	BDL	4.500	.	BDL	.	.
FEB	.	BDL	4.100	.	6.000	.	.
MAR	.	BDL	4.900	.	5.300	.	.
APR	.	BDL	6.200	.	6.200	.	.
MAY	.	!IV	5.000	.	5.900	.	.
JUN	.	BDL	5.000	.	!LA	.	.
JUL	.100 <T	.	5.200	.	5.800	.	.
AUG	BDL	.	5.900	.	7.100	.	.
SEP	BDL	.	5.100	.	7.200	.	.
OCT	BDL	.	4.200	.	5.900	.	.
NOV	BDL	.	4.900	.	5.600	.	.
DEC	BDL	.	3.900	.	.	.	5.000
T-CHLOROETHYLENE (UG/L)		**DET'N LIMIT = 0.05**		**GUIDELINE = 5 (D1)**			
JAN	.	BDL	BDL	.	BDL	.	.
FEB	.	BDL	BDL	.	BDL	.	.
MAR	.	BDL	BDL	.	BDL	.	.
APR	.	BDL	BDL	.	BDL	.	.
MAY	.	!IV	BDL	.	BDL	.	.
JUN	.	BDL	BDL	.	!LA	.	.
JUL	BDL	.	BDL	.	BDL	.	.
AUG	BDL	.	BDL	.	BDL	.	.
SEP	BDL	.	.050 <T	.	BDL	.	.
OCT	BDL	.	BDL	.	BDL	.	.
NOV	BDL	.	BDL	.	BDL	.	.
DEC	BDL	.	BDL	.	.	.	BDL
BROMOFORM (UG/L)		**DET'N LIMIT = 0.20**		**GUIDELINE = 350 (A1+)**			
JAN	.	BDL	1.000 <T	.	1.000 <T	.	.
FEB	.	BDL	.800 <T	.	.800 <T	.	.
MAR	.	BDL	.600 <T	.	.600 <T	.	.
APR	.	BDL	.800 <T	.	.600 <T	.	.
MAY	.	!IV	.600 <T	.	.800 <T	.	.
JUN	.	BDL	.400 <T	.	!LA	.	.
JUL	BDL	.	.800 <T	.	.600 <T	.	.
AUG	BDL	.	1.000 <T	.	1.000 <T	.	.
SEP	BDL	.	.800 <T	.	1.200 <T	.	.
OCT	BDL	.	.600 <T	.	.800 <T	.	.
NOV	BDL	.	.400 <T	.	.600 <T	.	.
DEC	BDL	.	.600 <T	.	.	.	.600 <T

TABLE 5
DRINKING WATER SURVEILLANCE PROGRAM HALDIMAND/NORFOLK WSS 1990

	WATER TREATMENT PLANT			DISTRIBUTION SYSTEM			
	RAW 1	RAW 2	TREATED	SITE 1		SITE 2	
				STANDING	FREE FLOW	STANDING	FREE FLOW
ETHLYENE DIBROMIDE (UG/L)			DET'N LIMIT = 0.05	GUIDELINE = 50 (D1)			
JAN	.	BDL	BDL	.	BDL	.	.
FEB	.	BDL	BDL	.	BDL	.	.
MAR	.	BDL	BDL	.	BDL	.	.
APR	.	BDL	BDL	.	BDL	.	.
MAY	.	IIV	BDL	.	BDL	.	.
JUN	.	BDL	BDL	.	ILA	.	.
JUL	BDL	.	BDL	.	.200 <T	.	.
AUG	BDL	.	BDL	.	BDL	.	.
SEP	BDL	.	BDL	.	BDL	.	.
OCT	BDL	.	BDL	.	BDL	.	.
NOV	BDL	.	BDL	.	BDL	.	.
DEC	BDL	.	BDL	.	.	.	BDL
TOTL TRIHALOMETHANES (UG/L)			DET'N LIMIT = 0.50	GUIDELINE = 350 (A1)			
JAN	.	BDL	31.000	.	34.400	.	.
FEB	.	BDL	17.450	.	33.700	.	.
MAR	.	BDL	30.400	.	33.950	.	.
APR	.	BDL	30.100	.	35.800	.	.
MAY	.	IIV	30.400	.	33.500	.	.
JUN	.	BDL	37.400	.	ILA	.	.
JUL	.600 <T	.	34.200	.	42.200	.	.
AUG	BDL	.	43.500	.	59.750	.	.
SEP	BDL	.	46.400	.	61.450	.	.
OCT	BDL	.	47.400	.	52.550	.	.
NOV	BDL	.	39.150	.	54.750	.	.
DEC	BDL	.	29.350	.	.	.	41.900

TRACE LEVELS OF TOLUENE ARE LABORATORY ARTIFACTS DERIVED FROM THE ANALYTICAL METHODOLOGY.

TRACE LEVELS OF STYRENE ARE CONSIDERED TO BE LABORATORY ARTIFACTS RESULTING FROM THE LABORATORY SHIPPING CONTAINERS.

TABLE 6
DRINKING WATER SURVEILLANCE PROGRAM 1990

SCAN/PARAMETER	UNIT	DETECTION LIMIT	GUIDELINE
BACTERIOLOGICAL			
FECAL COLIFORM MEMBRANE FILTRATION	CT/100ML	0	0 (A1)
STANDARD PLATE COUNT MEMBRANE FILT.	CT/ML	0	500/ML (A3)
TOTAL COLIFORM BACKGROUND MF	CT/100ML	0	N/A
TOTAL COLIFORM MEMBRANE FILTRATION	CT/100ML	0	5/100ML (A1)
CHEMISTRY (FLD)			
FIELD COMBINED CHLORINE RESIDUAL	MG/L	0	N/A
FIELD TOTAL CHLORINE RESIDUAL	MG/L	0	N/A
FIELD FREE CHLORINE RESIDUAL	MG/L	0	N/A
FIELD PH	DMNSLESS	N/A	6.5-8.5 (A3)
FIELD TEMPERATURE	DEG.C	N/A	15.0 (A3)
FIELD TURBIDITY	FTU	N/A	1.0 (A1)
CHEMISTRY (LAB)			
ALKALINITY	MG/L	0.2	30-500 (A3)
AMMONIUM TOTAL	MG/L	0.002	0.05 (F2)
CALCIUM	MG/L	0.2	100 (F2)
CHLORIDE	MG/L	0.2	250 (A3)
COLOUR	TCU	0.5	5.0 (A3)
CONDUCTIVITY	UMHO/CM	1.0	400 (F2)
CYANIDE	MG/L	0.001	0.2 (A1)
DISSOLVED ORGANIC CARBON	MG/L	0.1	5.0 (A3)
FLUORIDE	MG/L	0.01	2.4 (A1)
HARDNESS	MG/L	0.5	80-100 (A4)
LANGELIERS INDEX	DMNSLESS	N/A	N/A
MAGNESIUM	MG/L	0.1	30.0 (F2)
NITRITE	MG/L	0.001	1.0 (A1)
NITROGEN TOTAL KJELDAHL	MG/L	0.02	N/A
PH	DMNSLESS	N/A	6.5-8.5 (A4)
PHOSPHORUS FIL REACT	MG/L	0.0005	N/A
PHOSPHORUS TOTAL	MG/L	0.002	0.4 (F2)
SODIUM	MG/L	0.2	200 (A4)
SULPHATE	MG/L	0.2	500 (A3)
TOTAL NITRATES	MG/L	0.005	10.0 (A1)
TURBIDITY	FTU	0.05	1.0 (A1)
CHLOROAROMATICS			
123 TRICHLOROBENZENE	NG/L	5.0	N/A
1234 TETRACHLOROBENZENE	NG/L	1.0	N/A
1235 TETRACHLOROBENZENE	NG/L	1.0	N/A
124 TRICHLOROBENZENE	NG/L	5.0	10000 (I)
1245-TETRACHLOROBENZENE	NG/L	1.0	38000 (D4)
135 TRICHLOROBENZENE	NG/L	5.0	N/A
236 TRICHLOROTOLUENE	NG/L	5.0	N/A
245 TRICHLOROTOLUENE	NG/L	5.0	N/A
26A TRICHLOROTOLUENE	NG/L	5.0	N/A
HEXACHLOROBENZENE	NG/L	1.0	10 (C1)
HEXACHLOROBUTADIENE	NG/L	1.0	450 (D4)
HEXACHLOROCYCLOPENTADIENE	NG/L	5.0	206000 (D4)
HEXACHLOROETHANE	NG/L	1.0	1900 (D4)
OCTACHLOROSTYRENE	NG/L	1.0	N/A
PENTACHLOROBENZENE	NG/L	1.0	74000 (D4)
CHLOROPHENOLS			
234 TRICHLOROPHENOL	NG/L	100.0	N/A
2345 TETRACHLOROPHENOL	NG/L	20.0	N/A
2356 TETRACHLOROPHENOL	NG/L	10.0	N/A

TABLE 6
DRINKING WATER SURVEILLANCE PROGRAM 1990

SCAN/PARAMETER	UNIT	DETECTION LIMIT	GUIDELINE
245 TRICHLOROPHENOL	NG/L	100.0	2600000 (D4)
246 TRICHLOROPHENOL	NG/L	20.0	5000 (A1)
PENTACHLOROPHENOL	NG/L	10.0	60000 (A1)
METALS			
ALUMINUM	UG/L	0.10	100 (A4)
ANTIMONY	UG/L	0.05	146 (D4)
ARSENIC	UG/L	0.10	25 (A1)
BARIUM	UG/L	0.05	1000 (A2)
BERYLLIUM	UG/L	0.05	6800 (D4)
BORON	UG/L	2.00	5000 (A1)
CADMIUM	UG/L	0.05	5 (A1)
CHROMIUM	UG/L	0.50	50 (A1)
COBALT	UG/L	0.02	N/A
COPPER	UG/L	0.50	1000 (A3)
IRON	UG/L	6.00	300 (A3)
LEAD	UG/L	0.05	10 (A1)
MANGANESE	UG/L	0.05	50 (A3)
MERCURY	UG/L	0.02	1 (A1)
MOLYBDENUM	UG/L	0.05	N/A
NICKEL	UG/L	0.20	350 (D3)
SELENIUM	UG/L	1.00	10 (A1)
SILVER	UG/L	0.05	50 (A1)
STRONTIUM	UG/L	0.10	N/A
THALLIUM	UG/L	0.05	13 (D4)
TITANIUM	UG/L	0.50	N/A
URANIUM	UG/L	0.05	100 (A1)
VANADIUM	UG/L	0.05	N/A
ZINC	UG/L	0.20	5000 (A3)
PAH			
ANTHRACENE	NG/L	1.0	N/A
BENZO(A) ANTHRACENE	NG/L	20.0	N/A
BENZO(A) PYRENE	NG/L	5.0	10.0 (A1)
BENZO(B) CHRYSENE	NG/L	2.0	N/A
BENZO(B) FLUORANTHENE	NG/L	10.0	N/A
BENZO(E) PYRENE	NG/L	50.0	N/A
BENZO(G,H,I) PERYLENE	NG/L	20.0	N/A
BENZO(K) FLUORANTHENE	NG/L	1.0	N/A
CHRYSENE	NG/L	50.0	N/A
CORONENE	NG/L	10.0	N/A
DIBENZO(A,H) ANTHRACENE	NG/L	10.0	N/A
DIMETHYL BENZO(A) ANTHRACENE	NG/L	5.0	N/A
FLUORANTHENE	NG/L	20.0	42000.0 (D4)
INDENO(1,2,3-C,D) PYRENE	NG/L	20.0	N/A
PERYLENE	NG/L	10.0	N/A
PHENANTHRENE	NG/L	10.0	N/A
PYRENE	NG/L	20.0	N/A
PESTICIDES & PCB			
ALACHLOR (LASSO)	NG/L	500.0	5000 (A2)
ALDRIN	NG/L	1.0	700 (A1)
ALPHA HEXACHLOROCYCLOHEXANE (BHC)	NG/L	1.0	700 (G)
ALPHA CHLORDANE	NG/L	2.0	7000 (A1)
AMETRINE	NG/L	50.0	300000 (D3)
ATRATONE	NG/L	50.0	N/A
ATRAZINE	NG/L	50.0	60000 (A2)
DES ETHYL ATRAZINE	NG/L	200.0	60000 (A2)
BETA HEXACHLOROCYCLOHEXANE (BHC)	NG/L	1.0	300 (G)
CYANAZINE (BLADEX)	NG/L	100.0	10000 (A2)
O,P-DDD	NG/L	5.0	10 (I)
DIELDRIN	NG/L	2.0	700 (A1)
ENDOSULFAN 1 (THIODAN I)	NG/L	2.0	74000 (D4)
ENDOSULFAN 2 (THIODAN II)	NG/L	5.0	74000 (D4)

TABLE 6
DRINKING WATER SURVEILLANCE PROGRAM 1990

SCAN/PARAMETER	UNIT	DETECTION LIMIT	GUIDELINE
ENDOSULFAN SULPHATE (THIODAN SULPHATE)	NG/L	5.0	N/A
ENDRIN	NG/L	5.0	1600 (D3)
GAMMA CHLORDANE	NG/L	2.0	7000 (A1)
HEPTACHLOR	NG/L	1.0	3000 (A1)
HEPTACHLOR EPOXIDE	NG/L	1.0	3000 (A1)
LINDANE (GAMMA BHC)	NG/L	1.0	4000 (A1)
METHOXYCHLOR	NG/L	5.0	900000 (A1)
METOLACHLOR	NG/L	500.0	50000 (A2)
METRIBUZIN (SENCOR)	NG/L	100.0	80000 (A1)
MIREX	NG/L	5.0	N/A
P,P-DDD	NG/L	5.0	N/A
O,P-DDT	NG/L	5.0	30000 (A1)
OXYCHLORDANE	NG/L	2.0	N/A
PCB	NG/L	20.0	3000 (A2)
PPDDE	NG/L	1.0	30000 (A1)
PPDDT	NG/L	5.0	30000 (A1)
PROMETONE	NG/L	50.0	52500 (D3)
PROMETRYNE	NG/L	50.0	1000 (A2)
PROPAZINE	NG/L	50.0	700000 (D3)
SIMAZINE	NG/L	50.0	10000 (A2)
D-ETHYL SIMAZINE	NG/L	200.0	10000 (A2)
TOXAPHENE	NG/L	500.0	5000 (A1)
PHENOLICS			
PHENOLICS (UNFILTERED REACTIVE)	UG/L	0.2	2 (A4)
SPECIFIC PESTICIDES			
2,4 D PROPIONIC ACID	NG/L	100.	N/A
2,4,5-TRICHLOROPHENOXY ACETIC ACID	NG/L	50.	280000 (A1)
2,4-DICHLOROBUTYRIC ACID (2,4-D)	NG/L	100.	100000 (A1)
24-DICHLORORPHENOXYBUTYRIC ACID (24-DB)	NG/L	200.	18000 (B3)
BUTYLATE (SUTAN)	NG/L	2000.	245000 (D3)
CARBARYL (SEVIN)	NG/L	200.	90000 (A1)
CARBOFURAN	NG/L	2000.	90000 (A1)
CHLORPYRIFOS (DURSBAN)	NG/L	20.	N/A
CICP (CHLORPROPHAM)	NG/L	2000.	350000 (G)
DIALLATE	NG/L	2000.	N/A
DIAZINON	NG/L	20.	20000 (A1)
DICAMBA	NG/L	50.	120000 (A1)
DICHLOROVOS	NG/L	20.	N/A
EPTAM	NG/L	2000.	N/A
ETHION	NG/L	20.	35000 (G)
IPC	NG/L	2000.	N/A
MALATHION	NG/L	20.	190000 (A1)
METHYL PARATHION	NG/L	50.	7000 (B3)
METHYLTRITHION	NG/L	20.	N/A
MEVINPHOS	NG/L	20.	N/A
PARATHION	NG/L	20.	50000 (A1)
PHORATE (THIMET)	NG/L	20.	2000 (A2)
PROPOXUR (BAYGON)	NG/L	2000.	140000 (D3)
RELDAN	NG/L	20.	N/A
RONNEL	NG/L	20.	N/A
SILVEX (2,4,5-TP)	NG/L	20.	10000 (A1)
VOLATILES			
1,1 DICHLOROETHANE	UG/L	0.10	N/A
1,1 DICHLOROETHYLENE	UG/L	0.10	7 (D1)
1,2 DICHLOROBENZENE	UG/L	0.05	200 (A1)
1,2 DICHLOROETHANE	UG/L	0.05	5 (A1)

TABLE 6
DRINKING WATER SURVEILLANCE PROGRAM 1990

SCAN/PARAMETER	UNIT	DETECTION LIMIT	GUIDELINE
1,2 DICHLOROPROPANE	UG/L	0.05	5 (D1)
1,3 DICHLOROBENZENE	UG/L	0.10	3750 (D3)
1,4 DICHLOROBENZENE	UG/L	0.10	5 (A1)
111, TRICHLOROETHANE	UG/L	0.02	200 (D1)
112 TRICHLOROETHANE	UG/L	0.05	0.6 (D4)
1122 TETRACHLOROETHANE	UG/L	0.05	0.17(D4)
BENZENE	UG/L	0.05	5 (A1)
BROMOFORM	UG/L	0.20	350 (A1+)
CARBON TETRACHLORIDE	UG/L	0.20	5 (A1)
CHLOROBENZENE	UG/L	0.10	1510 (D3)
CHLORODIBROMOMETHANE	UG/L	0.10	350 (A1+)
CHLOROFORM	UG/L	0.10	350 (A1+)
DICHLOROBROMOMETHANE	UG/L	0.05	350 (A1+)
ETHLYENE DIBROMIDE	UG/L	0.05	50 (D1)
ETHYLBENZENE	UG/L	0.05	2.4 (A3)
M-XYLENE	UG/L	0.10	300 (A3*)
METHYLENE CHLORIDE	UG/L	0.50	50 (A1)
O-XYLENE	UG/L	0.05	300 (A3*)
P-XYLENE	UG/L	0.10	300 (A3*)
STYRENE	UG/L	0.05	100 (D1)
TETRACHLOROETHYLENE	UG/L	0.05	5 (D1)
TRANS 1,2 DICHLOROETHYLENE	UG/L	0.10	70 (D1)
TOLUENE	UG/L	0.05	24 (A3)
TOTAL TRIHALOMETHANES	UG/L	0.50	350 (A1)
TRICHLOROETHYLENE	UG/L	0.10	50 (A1)

Appendix A

DRINKING WATER SURVEILLANCE PROGRAM
PROGRAM DESCRIPTION

The Drinking Water Surveillance Program (DWSP) for Ontario monitors drinking water quality at municipal water supply systems. The DWSP Database Management System provides a computerized drinking water quality information system for the supplies monitored. The objectives of the program are to provide:

- immediate, reliable, current information on drinking water quality;
- a flagging mechanism for guideline exceedance;
- a definition of contaminant levels and trends;
- a comprehensive background for remedial action;
- a framework for assessment of new contaminants; and
- an indication of treatment efficiency of plant processes.

PROGRAM

The DWSP officially began in April 1986 and is designed to eventually include all municipal water supplies in Ontario. In 1990, 76 systems were being monitored. Water supply locations have been prioritized for surveillance based primarily on criteria such as population density, probability of contamination and geographical location.

An ongoing assessment of future monitoring requirements at each location will be made. Monitoring will continue at the initial locations at an appropriate level and further locations will be phased into the program as resources permit.

A major goal of the program is to collect valid water quality data in context with plant operational characteristics at the time of sampling. As soon as sufficient data have been accumulated and analyzed, both the frequency of sampling and the range of parameters may be adjusted accordingly.

Assessments are carried out at all locations prior to initial sampling, in order to acquire complete plant process and distribution system details and to designate (and retrofit if necessary) all sampling systems and locations. This ensures that the sampled water is a reflection of the water itself.

Samples are taken of raw (ambient water) and treated water at the treatment plant and of consumer's tap water in the distribution system. In order to determine possible effects of distribution on water quality, both standing and free flow water in old and new sections of the distribution system are sampled. Sampling is carried out by operational personnel who have been trained in applicable procedures.

Comprehensive standardized procedures and field test kits are supplied to sampling personnel. This ensures that samples are taken and handled according to standard protocols and that field testing will supply reliable data. All field and laboratory analyses are carried out using "approved documented procedures". Most laboratory analyses are carried out by the Ministry of Environment (MOE), Laboratory Services Branch. Radionuclides are analyzed by the Ministry of Labour.

DATA REPORTING MECHANISM

When the analytical results are transferred from the MOE laboratory into the DWSP system, printouts of the completed analyses are sent to the MOE District Officer, the appropriate operational staff and are also retained by the DWSP unit.

PROGRAM INPUTS AND OUTPUTS

There are four major inputs and four major outputs in the program.

Program Input - Plant and Distribution System Description

The system description includes plant specific non-analytical information acquired through a questionnaire and an initial plant visit. During the initial assessment of the plant and distribution system, questionnaire content is verified and missing information added. It is intended that all data be kept current with scheduled annual updates.

The Plant and Distribution System Description consists of the following seven components:

1. PROCESS COMPONENT INVENTORY
All physical and chemical processes to which the water is subjected, from the intake pipe to the consumers' tap (where possible), are documented. These include: process type, general description of physical structures, material types, sizes, and retention time for each process within the plant. The processes may be as simple as transmission or as complex as carbon adsorption.

2. TREATMENT CHEMICALS
Chemicals used in the treatment processes, their function, application point, supplier and brand-name are recorded. Chemical dosages applied on the day of sampling are recorded in DWSP.

3. PROCESS CONTROL MEASUREMENTS
Documentation of in-plant monitoring of process parameters (eg. turbidity, chlorine residuals, pH, aluminum residuals) including methods used, monitoring locations and frequency is contained in this section. Except for the recorded Field Data, in-plant monitoring results are not retained in DWSP but are retained by the water treatment plant personnel.

4. DESIGN FLOW AND RETENTION TIME
Hydraulic capacity, designed and actual, is noted here. Retention time (the time that a block of water is retained in the plant) is also noted. Maximum, minimum and average flow, as well as a record of the flow rate on the day of sampling, are recorded in DWSP.

5. DISTRIBUTION SYSTEM DESCRIPTION
This area includes the storage and transmission characteristics of the distribution system after the water leaves the plant.

6. SAMPLING SYSTEM
Each plant is assessed for its adequacy in terms of the sampling of bacteriological, organic and inorganic parameters. Prime considerations in the assessment and design of the sampling system are:

i/ the sample is an accurate representation of the actual water condition, eg. raw water has had no chemical treatment;

ii/ the water being sampled is not being modified by the sampling system;

iii/ the sample tap must be in a clean area of the plant, preferably a lab area; and

iv/ the sample lines must be organically inert (no plastic, ideally stainless steel).

It is imperative that the sampled water be a reflection not of the sampling system but of the water itself.

The sampling system documentation includes: origin of the water; date sampling was initiated; size, length and material type (intake,

discharge and tap); pump characteristics (model, type, capacity); and flow rate.

7. PERSONNEL
This section contains the names, addresses and phone numbers of current plant management and operational staff, distribution system management and operational staff, Medical Officer of Health and appropriate MOE personnel associated with the plant.

Program Input - Field Data

The second major input to DWSP is field data. Field data is collected at the plant and from the distribution system sites on the day of sampling. Field data consists of general operating conditions and the results of testing for field parameters. General operating conditions include chemicals used, dosages, flow and retention time on the day of sampling, as well as, monthly maximum, minimum and average flows. Field parameters include turbidity, chlorine residuals (free, combined and total), temperature and pH. These parameters are analyzed according to standardized DWSP protocols to allow for interplant comparison.

Program Input - Laboratory Analytical Data

The third major input to DWSP is Laboratory Analytical Data. Samples gathered from the raw, treated and distribution sampling sites are analyzed for the presence of approximately 180 parameters at a frequency of two to twelve times per year. Sixty-five percent of the parameters are organic. Parameters measured may have health or aesthetic implications when present in drinking water. Many of the parameters may be used in the treatment process or may be treatment by-products. Due to the nature of certain analytical instruments, parameters may be measured in a "scan" producing some results for parameters that are not on the DWSP priority list, but which may be of interest. The majority of parameters are measured on a routine basis. Those that are technically more difficult and/or costly to analyze, however, are done less frequently. These include Specific Pesticides and Chlorophenols.

Although the parameter list is extensive, additional parameters with the potential to cause health or aesthetic related problems may be added provided reliable analytical and sampling methods exist.

All laboratory generated data is derived from standardized, documented analytical protocols. The analytical method is an integral part of the data and as methods change, notation will be made and comparison data documented.

Program Input - Parameter Reference Information

The fourth major input to DWSP is Parameter Reference Information. This is a catalogue of information for each substance analyzed on DWSP. It includes parameter name and aliases, physical and chemical properties, basic toxicology, world-wide health limits, treatment methods and uses. The Parameter Reference Information is computerized and can be accessed through the Query function of the DWSP database. An example is shown in figure 1.

Program output - Query

All DWSP information is easily accessed through the Query function, therefore, anything from addresses of plant personnel to complete water quality information for a plant's water supply is instantly available. The DWSP computer system makes relatively complex inquiries manageable. A personal password allowing access into the DWSP query mode in all MOE offices is being developed by the DWSP group.

Program Output - Action Alerts

Drinking Water quality in Ontario is evaluated against provincial objectives as outlined in the Ontario Drinking Water Objectives publication. Should the reported level of a substance in treated water exceed the Ontario Drinking Water Objective, an "Action Alert" requiring resampling and confirmation is issued. This assures that operational staff, health authorities and the public are notified as soon as possible of the confirmation of an exceedance and remedial action taken. This report supplies a history of the occurrence of past exceedances at the plant plus a historical summary on the parameter of concern.

In the absence of Ontario Drinking Water Objectives, guidelines/limits from other agencies are used. The Parameter Listing System, published by MOE (ISBN 0-7729-4461-X), catalogues and keeps current guidelines for 650 parameters from agencies throughout the world. If these guidelines are exceeded, the results are flagged and evaluated by DWSP personnel. An "Action Alert" will be issued if warranted.

Program Output - Report Generation

Custom reports can be generated from DWSP to meet MOE Regional needs and to respond to public requests.

Program Output - Annual Reports

It is the practice of DWSP to produce an annual report containing analytical data along with companion plant information.

FIG.1

MOE - DRINKING WATER ASSESSMENT PROGRAM (DWSP)

PARAMETER REFERENCE INFORMATION

BENZENE (B2001P) VOLATILES

CLASS: HEALTH METHOD: P0C0D0 UNIT: µg/L

SOURCE	FROM	TO	METHOD	GUIDELINE	UNIT	NOTE
CAL C	85/01			0.700	µg/L	AL
CDWG C	87/01			5.000	µg/L	MAC
EPA C	87/07			5.000	µg/L	MCL
EPAA C	80/11			6.600	µg/L	AMBIENT **
FERC C	84/05			1.000	µg/L	MCL
WHO C	84/01			10.000	µg/L	GV

DESCRIPTION: **NAME:** BENZENE
CAS#: 71-43-2
MOLECULAR FORMULAE: C_6H_6
DETECTION LIMIT: (FOR METHOD POCODO) 0.05 µg/L
SYNONYMS: BENZOL; BENZOLE; COAL NAPHTHA; CARBON OIL (27). CYCLOHEXATRIENE (41).
CHARACTERISTICS: COLOURLESS TO LIGHT-YELLOW, MOBILE, NON-POLAR LIQUID, OF HIGHLY REFRACTIVE NATURE, AROMATIC ODOUR; VAPOURS BURN WITH SMOKING FLAME (30).
PROPERTIES: SOLUBILITY IN WATER: 1780-1800 mg/L AT 25C (41). THRESHOLD ODOUR: 0.5 - 10 PPM IN WATERTHRESHOLD TASTE: 0.5 mg/L IN WATER (39).
ENVIRONMENTAL FATE: MAY BIOACCUMULATE IN LIVING ORGANISMS AND APPEARS TO ACCUMULATE IN ANIMAL TISSUES THAT EXHIBIT A HIGH LIPID CONTENT OR REPRESENT MAJOR METABOLIC SITES, SUCH AS LIVER OR BRAIN; SMALL QUANTITIES EVAPORATE FROM SOILS OR ARE DEGRADED RATHER QUICKLY (80).
SOURCES: COMMERCIAL: PETROLEUM REFINING; SOLVENT RECOVERY; COAL TAR DISTILLATION (39); FOOD PROCESSING AND TANNING INDUSTRIES; COMBUSTION OF CAR EXHAUST.
ENVIRONMENTAL: POSSIBLE SOURCE IS RUNOFF.

USES: DETERGENTS; NYLON; INTERMEDIATE IN PRODUCTION OF OTHER COMPOUNDS, SUCH AS PESTICIDES; SOLVENT FOR EXTRACTION AND RECTIFICATION IN RUBBER INDUSTRY; DEGREASING AND CLEANSING AGENT; GASOLINE.

TOXICITY: RATING: 4 (VERY TOXIC).
ACUTE: IRRITATING TO MUCOUS MEMBRANES; SYMPTOMS INCLUDE RESTLESSNESS, CONVULSIONS, EXCITEMENT, DEPRESSION; DEATH MAY FOLLOW RESPIRATORY FAILURE.
CHRONIC: MAY CAUSE ANAEMIA AND LEUKAEMIA (45); MUTAGENIC.
MODE OF ACTION: CHROMOABERRATION IN LYMPHOCYTE CULTURES.

CARCINOGENICITY: A KNOWN HUMAN CARCINOGEN.

REMOVAL: THE FOLLOWING PROCESSES HAVE BEEN SUCCESSFUL IN REMOVING BENZENE FROM WASTEWATER: GAC ADSORPTION, PRECIPITATION WITH ALUM AND SUBSEQUENT REMOVAL VIA SEDIMENTATION, COAGULATION AND FLOCCULATION, SOLVENT EXTRACTION, OXIDATION

ADDITIONAL PROPERTIES:
MOLECULAR WEIGHT: 78.12
MELTING POINT: 5.5°C (27).
BOILING POINT: 80.1°C (27).
SPECIFIC GRAVITY: 0.8790 AT 20°C (27).
VAPOUR PRESSURE: 100 MM AT 26.1°C (27).
HENRY'S LAW CONSTANT: 0.00555 ATM-M3/MOLE (41).
LOG OCT./WATER PARTITION COEFFICIENT: 1.95 TO 2.13 (39).
CARBON ADSORPTION: K=1.0; 1/N=1.6; R=0.97; PH=5.3 (41)SEDIMENT/WATER PARTITION COEFFICIENT: NO DATA

NOTES: EPA PRIORITY POLLUTANT.

Appendix B

DWSP SAMPLING GUIDELINE

i) Raw and Treated at Plant

General Chemistry	-500 mL plastic bottle (PET 500) -rinse bottle and cap with sample water three times -fill to 2 cm from top
Bacteriological	-220 mL plastic bottle with white seal on cap -do not rinse bottle, preservative has been added -avoid touching bottle neck or inside of cap -fill to top of red label as marked
Metals	-500 mL plastic bottle (PET 500) -rinse bottle and cap three times -fill to 2 cm from top -add 10 drops nitric acid (HNO_3) (**Caution:** HNO_3 is corrosive)
Volatiles (duplicates) (OPOPUP)	-45 mL glass vial with septum (teflon side must be in contact with sample) -do not rinse bottle -fill bottle completely without bubbles
Organics (OWOC),(OWTRI),(OAPAHX)	-1 L amber glass bottle per scan -do not rinse bottle -fill to 2 cm from top -when 'special pesticides' are requested three extra bottles must be filled

Cyanide	-500 mL plastic bottle (PET 500) -rinse bottle and cap three times -fill to 2 cm from top -add 10 drops sodium hydroxide (NaOH) (**Caution:** NaOH is corrosive)
Mercury	-250 mL glass bottle -rinse bottle and cap three times -fill to top of label -add 20 drops each nitric acid (HNO_3) and potassium dichromate ($K_2Cr_2O_7$) (**Caution:** HNO_3&$K_2Cr_2O_7$ are corrosive)
Phenols	-250 mL glass bottle -do <u>not</u> rinse bottle, preservative has been added -fill to top of label
Radionuclides (as scheduled)	-4 L plastic jug -do <u>not</u> rinse, carrier added -fill to 5 cm from top
Organic Characterization (GC/MS - once per year)	-1 L amber glass bottle; instructions as per organic -250 mL glass bottle -do <u>not</u> rinse bottle -fill completely without bubbles

<u>Steps:</u>

1. Let sampling water tap run for an adequate time to clear the sample line.

2. Record time of day on submission sheet.

3. Record temperature on submission sheet.

4. Fill up all bottles as per instructions.

5. Record chlorine residuals (free, combined and total for treated water only), turbidity and pH on submission sheet.

ii) Distribution Samples (standing water)

General Chemistry	-500 mL plastic bottle (PET 500) -rinse bottle and cap with sample water three times -fill to 2 cm from top
Metals	-500 mL plastic bottle (PET 500) -rinse bottle and cap three times -fill to 2 cm from top -add 10 drops nitric acid (HNO_3) (**Caution:** HNO_3 is corrosive)

Steps:

1. Record time of day on submission sheet.
2. Place bucket under tap and open cold water.
3. Fill to predetermined volume.
4. After mixing the water, record the temperature on the submission sheet.
5. Fill general chemistry and metals bottles.
6. Record chlorine residuals (free, combined and total), turbidity and pH on submission sheet.

iii) Distribution Samples (free flow)

General Chemistry	-500 mL plastic bottle (PET 500) -rinse bottle and cap with sample water three times -fill to 2 cm from top
Bacteriological	-250 mL plastic bottle with white seal on cap -do not rinse bottle, preservative has been added -avoid touching bottle neck or inside of cap -fill to top of red label as marked

Metals	-500 mL plastic bottle (PET 500) -rinse bottle and cap three times -fill to 2 cm from top -add 10 drops nitric acid HNO_3 (**Caution:** HNO_3 is corrosive)
Volatiles (duplicate) (OPOPUP)	-45 mL glass vial with septum (teflon side must be in contact with sample) -do <u>not</u> rinse bottle, preservative has been added -fill bottle completely without bubbles
Organics (OWOC) (OAPAHX)	-1 L amber glass bottle per scan -do <u>not</u> rinse bottle -fill to 2 cm from top

<u>Steps:</u>

1. Record time of day on submission sheet.

2. Let cold water flow for five minutes.

3. Record temperature on submission sheet.

4. Fill all bottles as per instructions.

5. Record chlorine residuals (free, combined and total), turbidity and pH on submission sheet.